

## PALEXTRA 44 Machine Id SULLIVAN PALATEK 21JE002498 - INERTIA ENGINEERING Component Compressor

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Besample at the next service interval to monitor	Sample Number		Client Info		UCS06159232	UCS06081456	UCS05859372
	Sample Date		Client Info		20 Mar 2024	14 Dec 2023	14 Mar 2023
	Machine Age	hrs	Client Info		0	5233	3256
	Oil Age	hrs	Client Info		0	0	0
	Filter Age	hrs	Client Info		0	0	0
	Oil Changed		Client Info		Not Changd	N/A	Not Changd
	Filter Changed		Client Info		Changed	N/A	Changed
	Sample Status				NORMAL	NORMAL	NORMAL
WEAD							
WEAR	Iron	ppm	ASTM D5185m	>50	0	0	0
All component wear rates are normal.	Chromium	ppm	ASTM D5185m	>10	<1	0	0
	Nickel	ppm	ASTM D5185m		<1	0	0
	Titanium	ppm	ASTM D5185m		<1	0	0
	Silver	ppm	ASTM D5185m	0.7	0	0	0
	Aluminum	ppm	ASIM D5185m	>25	2	<1	0
	Lead	ppm	ASTM D5185m	>25	<1	0	0
	Copper	ppm	ASIM D5185m	>50	1	<1	0
	l in	ppm	ASTM D5185m	>15	<1	0	<1
	Vanadium	ppm	ASTM D5185m		<1	<1	0
	White Metal	scalar	*Visual	NONE	LIGHT	NONE	LIGHT
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
CONTAMINATION	Silicon	ppm	ASTM D5185m	>25	6	5	4
There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185m	>20	<1	3	2
	Water		WC Method	>0.1	NEG	NEG	NEG
	Silt	scalar	*Visual	NONE	NONE	NONE	NONE
	Debris	scalar	*Visual	NONE	NONE	NONE	NONE
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
	Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
	Odor	scalar	*Visual	NORML	NORML	NORML	NORML
	Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
FLUID CONDITION	Sodium	ppm	ASTM D5185m		<1	<1	<1
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.	Boron	ppm	ASTM D5185m	0	0	0	0
	Barium	ppm	ASTM D5185m	0.3	0	0	1
	Molybdenum	ppm	ASTM D5185m	0	<1	0	0
	Manganese	ppm	ASTM D5185m	0.3	0	<1	<1
	Magnesium	ppm	ASTM D5185m	0.4	<1	0	0
	Calcium	ppm	ASTM D5185m	0	3	0	0
	Phosphorus	ppm	ASTM D5185m	689	600	533	591
	Zinc	ppm	ASTM D5185m	0	0	0	0
	Sulfur	ppm	ASTM D5185m	1237	1076	875	1270
	Acid Number (AN)	mg KOH/g	ASTM D8045	0.135	0.16	0.411	0.05

Contact/Location: CHRISTO GINGRAS - UCCOMSTO

43.9

43.1

Visc @ 40°C cSt ASTM D445 44.62

43.3



Sample No. : UCS06159232 Received 4772 FRONTIER WAY UNIT 400 : 24 Apr 2024 Lab Number : 06159232 Tested STOCKTON, CA : 25 Apr 2024 Unique Number : 10994655 Diagnosed : 26 Apr 2024 - Jonathan Hester US 95215 Test Package : IND 2 Contact: CHRISTO GINGRAS Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. christo@complete-es.net \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: (800)701-3196 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (209)753-4211

Contact/Location: CHRISTO GINGRAS - UCCOMSTO Page 2 of 2