

ULTRA COOLANT Machine Id INGERSOLL RAND CBV849946 Component Compressor

RECOMMENDATION

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

WEAR

All component wear rates are normal.

CONTAMINATION


Elemental level of silicon (Si) above normal.

FLUID CONDITION

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		UAC06160462		
Sample Date		Client Info		12 Apr 2024		
Machine Age	hrs	Client Info		6075		
Oil Age	hrs	Client Info		0		
Filter Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Filter Changed		Client Info		Changed		
Sample Status				ABNORMAL		
Iron	ppm	ASTM D5185m	>50	6		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	2		
Lead	ppm	ASTM D5185m	>25	1		
Copper	ppm	ASTM D5185m	>50	2		
Tin	ppm	ASTM D5185m	>15	1		
Vanadium	ppm	ASTM D5185m		<1		
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Silicon	ppm	ASTM D5185m	>25	▲ 25		
Potassium	ppm	ASTM D5185m	>20	8		
Water		WC Method	>0.1	NEG		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.1	NEG		
Sodium	ppm	ASTM D5185m		89		
Boron		ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	500	710		
Molybdenum	ppm	ASTM D5185m		1		
Manganese	ppm	ASTM D5185m	0	י <1		
Magnesium	ppm	ASTM D5185m	0	2		
Calcium	ppm	ASTM D5185m	0	2 25		
	ppm			25		
Phosphorus	ppm	ASTM D5185m	20			
Zinc	ppm	ASTM D5185m	0	61 267		
Sulfur	ppm	ASTM D5185m	200	367		
Acid Number (AN)	mg KOH/g cSt	ASTM D8045 ASTM D445	49.4	0.519 54.1		
Visc @ 40°C				5/1		

Contact/Location: Derik Bray - UCATLHOS



ATLANTA AIR COMPRESSOR Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 Sample No. : UAC06160462 Received : 25 Apr 2024 123 MERCHANTS PARK DR Lab Number : 06160462 Tested HOSCHTON, GA : 26 Apr 2024 Unique Number : 10995885 Diagnosed : 26 Apr 2024 - Sean Felton US 30548 Test Package : IND 2 Contact: Derik Bray Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. Derik@atlantaaircompressor.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: (470)252-9952 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: x:

Contact/Location: Derik Bray - UCATLHOS Page 2 of 2