WEAR CONTAMINATION **FLUID CONDITION** **ABNORMAL NORMAL NORMAL**

Machine Id **LUDLOW**

DIESEL ENGINE OIL SAE 15W40 (GAL)							
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.	Sample Number		Client Info		MW0062722	MW0057086	MW004826
	Sample Date		Client Info		23 Apr 2024	07 Feb 2024	23 Dec 202
	Machine Age	hrs	Client Info		23005	22375	21742
	Oil Age	hrs	Client Info		500	500	500
	Filter Age	hrs	Client Info		500	500	500
	Oil Changed		Client Info		Changed	Changed	Changed
	Filter Changed		Client Info		Changed	Changed	Changed
	Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR The copper level is abnormal. Cylinder, crank, or cam shaft wear is indicated. In the absence of other significant wear metals, suspect copper due to sources other than wear (i.e. cooling core).	Iron	ppm	ASTM D5185m	>50	4 76	37	9
	Chromium	ppm	ASTM D5185m	>4	1	<1	<1
	Nickel	ppm	ASTM D5185m		<1	<1	0
	Titanium	ppm	ASTM D5185m		<1	0	<1
	Silver	ppm	ASTM D5185m	>5	0	0	0
	Aluminum	ppm	ASTM D5185m	>12	6	8	4
	Lead	ppm	ASTM D5185m	>17	<1	0	0
	Copper	ppm	ASTM D5185m	>70	149	0	<1
	Tin	ppm	ASTM D5185m	>15	<1	<1	<1
	Vanadium	ppm	ASTM D5185m		<1	<1	0
	White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
CONTAMINATION There is no indication of any contamination in the oil.	Silicon	ppm	ASTM D5185m	>25	9	11	8
	Potassium	ppm	ASTM D5185m	>20	2	<1	1
	Fuel		WC Method	>4.0	<1.0	<1.0	<1.0
	Water		WC Method	>0.1	NEG	NEG	NEG
	Glycol		WC Method		NEG	NEG	NEG
	Soot %	%	*ASTM D7844		0.2	1.1	0.1
	Nitration	Abs/cm	*ASTM D7624	>20	11.2	12.4	11.6
	Sulfation	Abs/.1mm	*ASTM D7415	>30	27.0	28.3	26.0
	Silt	scalar	*Visual	NONE	NONE	NONE	NONE
	Debris	scalar	*Visual	NONE	NONE	NONE	NONE
		scalar	*Visual	NONE	NONE	NONE	NONE
	Sand/Dirt						NORM
	Appearance	scalar	*Visual	NORML	NORML	NORML	110011
	Appearance Odor	scalar	*Visual	NORML	NORML	NORML	
	Appearance	scalar					NORM NEG
FLUID CONDITION	Appearance Odor	scalar	*Visual	NORML >0.1	NORML	NORML	
	Appearance Odor Emulsified Water	scalar scalar	*Visual *Visual	NORML >0.1 >158	NORML NEG	NORML NEG	
FLUID CONDITION The BN result indicates that there is suitable alkalinity remaining in the condition of the cill is acceptable for the time in service.	Appearance Odor Emulsified Water Sodium	scalar scalar ppm	*Visual *Visual ASTM D5185m ASTM D5185m ASTM D5185m	NORML >0.1 >158 250 10	NORML NEG	NORML NEG 2	NEG 3
	Appearance Odor Emulsified Water Sodium Boron	scalar scalar ppm ppm	*Visual *Visual ASTM D5185m ASTM D5185m	NORML >0.1 >158 250 10	NORML NEG 1 385	NORML NEG 2 276	3 232
The BN result indicates that there is suitable alkalinity remaining in the	Appearance Odor Emulsified Water Sodium Boron Barium	scalar scalar ppm ppm ppm	*Visual *Visual ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	NORML >0.1 >158 250 10 100	NORML NEG 1 385 0 124 <1	NORML NEG 2 276 0 128 <1	NEG 3 232 0 121 <1
The BN result indicates that there is suitable alkalinity remaining in the	Appearance Odor Emulsified Water Sodium Boron Barium Molybdenum Manganese Magnesium	scalar scalar ppm ppm ppm	*Visual *Visual ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	NORML >0.1 >158 250 10 100	NORML NEG 1 385 0 124 <1 621	NORML NEG 2 276 0 128 <1 699	NEG 3 232 0 121 <1 653
The BN result indicates that there is suitable alkalinity remaining in the	Appearance Odor Emulsified Water Sodium Boron Barium Molybdenum Manganese Magnesium Calcium	scalar scalar ppm ppm ppm ppm	*Visual *Visual ASTM D5185m	NORML >0.1 >158 250 10 100 450 3000	NORML NEG 1 385 0 124 <1 621 1496	NORML NEG 2 276 0 128 <1 699 1521	NEG 3 232 0 121 <1 653 1568
The BN result indicates that there is suitable alkalinity remaining in the	Appearance Odor Emulsified Water Sodium Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus	scalar scalar ppm ppm ppm ppm ppm	*Visual *Visual *Visual ASTM D5185m	NORML >0.1 >158 250 10 100 450 3000 1150	NORML NEG 1 385 0 124 <1 621 1496 742	NORML NEG 2 276 0 128 <1 699 1521 711	NEG 3 232 0 121 <1 653 1568 656
The BN result indicates that there is suitable alkalinity remaining in the	Appearance Odor Emulsified Water Sodium Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc	scalar scalar ppm ppm ppm ppm ppm ppm ppm ppm ppm	*Visual *Visual ASTM D5185m	NORML >0.1 >158 250 10 100 450 3000 1150 1350	NORML NEG 1 385 0 124 <1 621 1496	NORML NEG 2 276 0 128 <1 699 1521 711 875	NEG 3 232 0 121 <1 653 1568 656 828
The BN result indicates that there is suitable alkalinity remaining in the	Appearance Odor Emulsified Water Sodium Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur	scalar scalar ppm ppm ppm ppm ppm ppm ppm ppm	*Visual *Visual ASTM D5185m	NORML >0.1 >158 250 10 100 450 3000 1150 1350 4250	NORML NEG 1 385 0 124 <1 621 1496 742 852 2636	NORML NEG 2 276 0 128 <1 699 1521 711 875 2367	NEG 3 232 0 121 <1 653 1568 656 828 2261
The BN result indicates that there is suitable alkalinity remaining in the	Appearance Odor Emulsified Water Sodium Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc	scalar scalar ppm ppm ppm ppm ppm ppm ppm ppm ppm	*Visual *Visual ASTM D5185m	NORML >0.1 >158 250 10 100 450 3000 1150 1350 4250	NORML NEG 1 385 0 124 <1 621 1496 742 852	NORML NEG 2 276 0 128 <1 699 1521 711 875	3 232 0 121 <1 653 1568 656 828

Base Number (BN) mg KOH/g ASTM D2896 8.5

ASTM D445 14.4

Visc @ 100°C cSt

8.1


14.6

8.3

12.8

7.3

13.7







Certificate L2367

Laboratory Sample No. Lab Number : 06174858 Unique Number : 11020911

Test Package : MAR 2

: MW0062722

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Received **Tested** Diagnosed

: 09 May 2024

: 10 May 2024

: 13 May 2024 - Sean Felton

C & B MARINE 50 E RIVERCENTER BLVD, SUITE 1180

COVINGTON, KY US 41011

Contact: DAVID WESTRICH

dwestrich@carlislebray.com T: (812)290-4063

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. F: (859)655-7504 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)