



COOLANT REPORT

CORROSION	NORMAL
CONTAMINANTS	NORMAL
COOLANT CONDITION	NORMAL

Area
[PMOAS2771878]
 Machine Id
SD500 3004006682
 Component
Coolant
 Fluid
CONVENTIONAL COOLANT (--- QTS)

RECOMMENDATION

The fluid is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		DC0023229	DC0023244	DC0017043
Sample Date		Client Info		24 Apr 2024	03 Apr 2023	10 Feb 2022
Machine Age	hrs	Client Info		164	143	101
Oil Age	hrs	Client Info		22	0	18
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				NORMAL	NORMAL	NORMAL








CORROSION

Total Dissolved Solids				238.5	258.0	280.5
Coolant Appearance		*Visual	Clear	normal	normal	normal

CONTAMINANTS

There is no indication of any contamination in the coolant.

Boiling Point	°C	WC Method		226	---	---
Specific Gravity		*ASTM D1298		1.069	1.070	---
pH	Scale 0-14	ASTM D1287		8.01	8.13	8.04
Nitrites	ppm	AP-053:2009		1388	1388	1352
Reserve Alkalinity	Scale 0-20	*ASTM D1121		---	---	---
Percentage Glycol	%	ASTM D3321		51.7	52.4	49
Freezing Point	°F	ASTM D3321		-38	-40	-35
Carboxylate				n/a	n/a	n/a
Coolant Color		*Visual		Pink	Pink	Pink



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : DC0023229
Lab Number : 06176007
Unique Number : 11022060
Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType)

KELLY GENERATOR & EQUIPMENT INC
 1955 DALE LN
 OWINGS, MD
 US 20736
 Contact: LESLIE SNURR
 LSNURR@KGE.COM
 T: (410)257-5225
 F: (410)257-5227

*To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)*