



OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Machine Id
JOHN DEERE E-55
 Component
Diesel Engine
 Fluid
SHELL ROTELLA T 15W40 (5 GAL)

RECOMMENDATION

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		LEC0049428	LEC0026600	LEC0003411
Sample Date		Client Info		08 May 2024	03 Oct 2022	30 Sep 2019
Machine Age	hrs	Client Info		5077	3683	1080
Oil Age	hrs	Client Info		400	3114	569
Filter Age	hrs	Client Info		400	3114	569
Oil Changed		Client Info		Changed	Changed	Changed
Filter Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	ABNORMAL

WEAR

All component wear rates are normal.

Iron	ppm	ASTM D5185m	>51	30	26	23
Chromium	ppm	ASTM D5185m	>11	<1	<1	<1
Nickel	ppm	ASTM D5185m	>5	<1	3	2
Titanium	ppm	ASTM D5185m		0	<1	<1
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>31	4	4	7
Lead	ppm	ASTM D5185m	>26	0	<1	<1
Copper	ppm	ASTM D5185m	>26	<1	2	▲ 80
Tin	ppm	ASTM D5185m	>4	<1	2	0
Vanadium	ppm	ASTM D5185m		0	1	0
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE

CONTAMINATION








There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185m	>120	8	13	7
Potassium	ppm	ASTM D5185m	>20	0	1	0
Fuel		WC Method	>2.1	<1.0	<1.0	<1.0
Water		WC Method	>0.21	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
Soot %	%	*ASTM D7844	>3	0.5	0.6	0.4
Nitration	Abs/cm	*ASTM D7624	>20	9.4	10.3	10.1
Sulfation	Abs/.1mm	*ASTM D7415	>30	24.7	25.2	22.5
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.21	NEG	NEG	NEG

FLUID CONDITION

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185m	>31	3	5	5
Boron	ppm	ASTM D5185m	316	305	140	106
Barium	ppm	ASTM D5185m	0.0	1	0	0
Molybdenum	ppm	ASTM D5185m	1.2	100	113	195
Manganese	ppm	ASTM D5185m		<1	<1	1
Magnesium	ppm	ASTM D5185m	24	535	554	819
Calcium	ppm	ASTM D5185m	2292	1514	1552	1340
Phosphorus	ppm	ASTM D5185m	1064	1180	886	798
Zinc	ppm	ASTM D5185m	1160	1347	1085	1039
Sulfur	ppm	ASTM D5185m	4996	3766	2937	2122
Oxidation	Abs/.1mm	*ASTM D7414	>25	20.0	20.1	18.2
Base Number (BN)	mg KOH/g	ASTM D2896	10.1	7.4	8.3	8.3
Visc @ 100°C	cSt	ASTM D445	15.7	14.1	14.5	14.4



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : LEC0049428 **Received** : 14 May 2024
Lab Number : 06178472 **Tested** : 15 May 2024
Unique Number : 11029798 **Diagnosed** : 15 May 2024 - Wes Davis
Test Package : CONST (Additional Tests: TBN)

APEX PIPELINE
P.O. BOX 580
NITRO, WV
US 25143
Contact: KELLY TUCKER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (304)204-0080
F: (304)204-0083