
**WEAR** CONTAMINATION **FLUID CONDITION** 

**NORMAL ABNORMAL NORMAL** 

Machine Id

## KAESER ASD 30 2695314 (S/N 1169) Compressor Fluid

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
0" 1" 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	Sample Number		Client Info		KCPA013384	KCP48706	KCP30072
Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.	Sample Date		Client Info		03 May 2024		05 Apr 202
	Machine Age	hrs	Client Info		26661	23863	20962
	Oil Age	hrs	Client Info		0	1245	2158
	Filter Age	hrs	Client Info		0	1245	2158
	Oil Changed		Client Info		Changed	Changed	Changed
	Filter Changed Sample Status		Client Info		Changed ABNORMAL	Changed NORMAL	Changed NORMAL
WEAD	lunu.		AOTA DE LOS		40	00	40
WEAR	Iron	ppm	ASTM D5185m		16	20	13
All component wear rates are normal.	Chromium Nickel	ppm	ASTM D5185m		0	0	0
	Titanium	ppm	ASTM D5185m ASTM D5185m		<1 <1	0	0
	Silver	ppm	ASTM D5185m		<1 <1	0	0
	Aluminum	ppm	ASTM D5185m		1	2	0
	Lead	ppm	ASTM D5185m		- 1 <1	0	<1
	Copper	ppm	ASTM D5185m		6	5	4
	Tin	ppm	ASTM D5185m		0	0	<1
	Vanadium	ppm	ASTM D5185m	710	<1	0	0
	White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
CONTAMINATION	Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
	Potassium	ppm	ASTM D5185m	>20	0	0	<1
There is a high amount of particulates present in the oil.	Water	%	ASTM D6304	>0.05	0.003	0.003	0.006
	ppm Water	ppm	ASTM D6304	>500	33	38.1	64.5
	Particles >4µm		ASTM D7647		9389	318	2675
	Particles >6μm		ASTM D7647		<u> </u>	65	506
	Particles >14μm		ASTM D7647	>80	<b>△</b> 355	6	48
	Particles >21µm		ASTM D7647		<u> </u>	2	16
	Particles >38μm		ASTM D7647		4	0	1
	Particles >71µm		ASTM D7647		0	0	0
	Oil Cleanliness		ISO 4406 (c)	>/17/13	A 20/19/16	13/10	16/13 NONE
	Silt Debris	scalar	*Visual *Visual	NONE	NONE NONE	NONE NONE	NONE
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
	Appearance	scalar scalar	*Visual	NORML	NORML	NORML	NORM
	Odor	scalar	*Visual	NORML	NORML	NORML	NORM
	Emulsified Water			>0.05	NEG	NEG	NEG
······			VISUAI				
FLUID CONDITION	Sodium	ppm	ASTM D5185m		2	<1	0
	Boron	ppm	ASTM D5185m		0	<1	0
The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.	Barium	ppm	ASTM D5185m		0	0	0
	Molybdenum	ppm	ASTM D5185m		0	0	0
	Manganese	ppm	ASTM D5185m		<1	<1	0
	Magnesium	ppm	ASTM D5185m		<1	0	1
	Calcium	ppm	ASTM D5185m		0	0	0
	Phosphorus	ppm	ASTM D5185m	500	433	448	333
	Zinc	ppm	ASTM D5185m		249	261	209
	Sulfur	ppm	ASTM D5185m		2577	1399	1667
	Acid Number (AN)	mg KOH/g	ASTM D8045		1.48	1.36	1.169
	Visc @ 40°C	cSt	ASTM D445	46	46.2	46.98	44.9





Certificate L2367

Laboratory Sample No. Lab Number

: KCPA013384 : 06186708

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Received **Tested** Unique Number : 11043460 Diagnosed : 21 May 2024

: 23 May 2024

: 23 May 2024 - Angela Borella Test Package: IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**ALTIUM PACKAGING** 

3865 GRAPE ST DENVER, CO US 80207

Contact: Service Manager

Contact/Location: Service Manager - CONDENCO

T: