

**CORROSION CONTAMINANTS FUEL CONDITION** 


**NORMAL ABNORMAL** NORMAL


[NCPM03035679]

DETROIT 23.9L 250054 (S/N 0688849)
Diesel Fuel

DIESEL ENGINE OIL SAE 15W40 (--- QTS)

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid.	Test Sample Number Sample Date Machine Age Sample Status	UOM	Method Client Info Client Info Client Info	Limit/Abn	Current DC0028725	History1	History2
component, and use off-line filtration to improve the cleanliness of the system fluid.	Sample Date Machine Age	hrs	Client Info		DC0028725		
system fluid.	Machine Age	hrs					
COPPOSION	· ·	hrs	Client Info		10 May 2024		
COPPOSION	Sample Status		3		1413		
COPPOSION					ABNORMAL		
7/V/a1a1V/a1/V/	Aluminum	ppm	ASTM D5185m	-∩ 1	0		
All metal levels are normal indicating no corrosion in the system.	Nickel	ppm	ASTM D5185m		0		
	Lead	ppm	ASTM D5105m		0		
	Vanadium	ppm	ASTM D5185m		0		
	Iron	ppm	ASTM D5185m		0		
Free water present. Moderate concentration of visible dirt/debris present in the fuel. There is no bacteria or fungus (yeast and/or mold) present in the sample.	Silicon	ppm	ASTM D5185m	<1.0	<1		
	Sodium	ppm	ASTM D5185m	<0.1	0		
	Potassium	ppm	ASTM D5185m	<0.1	0		
	Water	%	ASTM D6304	<0.05	0.002		
	ppm Water	ppm	ASTM D6304	<500	22		
	% Gasoline	%	*In-House	<0.50	0.0		
	% Biodiesel	%	*In-House	<20.0	0.0		
	Bacteria	CFU/ml	WC-Method	>=100000	0		
	Yeast	CFU/ml	WC-Method	>=100000	0		
	Mold	Colonies	WC-Method	MODER			
	Calcium	ppm	ASTM D5185m	<0.1	0		
	Magnesium	ppm	ASTM D5185m	<0.1	0		
	Phosphorus	ppm	ASTM D5185m	<0.1	16		
	Zinc	ppm	ASTM D5185m	<0.1	0		
FUEL CONDITION	ASTM Color	scalar	*ASTM D1500		L4.5		
Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.	Visc @ 40°C	cSt	ASTM D445	115	2.46		
	Sulfur	ppm	ASTM D5185m	4250	0		
	Sulfur (UVF)	ppm	ASTM D5453		8		
	API Gravity	1.1	ASTM D7777		36.9		







Certificate L2367

Report Id: KELOWI [WUSCAR] 06188178 (Generated: 06/07/2024 10:54:27) Rev: 1

Laboratory Sample No. Unique Number : 11044930

: DC0028725 Lab Number : 06188178

Received **Tested** Diagnosed

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : 22 May 2024

: 04 Jun 2024

: 04 Jun 2024 - Doug Bogart

**KELLY GENERATOR & EQUIPMENT INC** 1955 DALE LN OWINGS, MD

US 20736 Test Package : DF-5 ( Additional Tests: API, Bacteria, Cetane, Fuel, Glycol, PrtCount, ScreetContact: LESLIE SNURR To discuss this sample report, contact Customer Service at 1-800-237-1369. LSNURR@KGE.COM

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) T: (410)257-5225 F: (410)257-5227