



PERFORMANCE  
UNDER  
PRESSURE

OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Machine Id  
**TOLE\_U2 TOLE\_U2\_P2**  
Component  
**Non-Drive End Pump**  
Fluid  
**ROYAL PURPLE SYNFILM GT 32 (2 QTS)**

**RECOMMENDATION**

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>RP0029079</b>	RP0025900	RP0034038
Sample Date		Client Info		<b>15 May 2024</b>	21 Feb 2024	16 Nov 2023
Machine Age	hrs	Client Info		<b>0</b>	0	0
Oil Age	hrs	Client Info		<b>0</b>	0	0
Filter Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed		Client Info		<b>N/A</b>	N/A	N/A
Filter Changed		Client Info		<b>N/A</b>	N/A	N/A
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL

**WEAR**

All component wear rates are normal.

Iron	ppm	ASTM D5185m	>90	<b>1</b>	<1	0
Chromium	ppm	ASTM D5185m	>5	<b>&lt;1</b>	0	0
Nickel	ppm	ASTM D5185m	>5	<b>0</b>	0	<1
Titanium	ppm	ASTM D5185m	>3	<b>&lt;1</b>	0	0
Silver	ppm	ASTM D5185m	>3	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>7	<b>2</b>	0	<1
Lead	ppm	ASTM D5185m	>12	<b>4</b>	3	4
Copper	ppm	ASTM D5185m	>30	<b>23</b>	24	26
Tin	ppm	ASTM D5185m	>9	<b>&lt;1</b>	0	<1
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE

**CONTAMINATION**








The water content is negligible. There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185m	>60	<b>1</b>	1	<1
Potassium	ppm	ASTM D5185m	>20	<b>1</b>	0	<1
Water	%	ASTM D6304	>.1	<b>0.020</b>	0.007	0.010
ppm Water	ppm	ASTM D6304	>1000	<b>201</b>	75	102
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>.1	<b>NEG</b>	NEG	NEG

**FLUID CONDITION**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185m		<b>0</b>	2	2
Boron	ppm	ASTM D5185m		<b>0</b>	0	0
Barium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Manganese	ppm	ASTM D5185m		<b>0</b>	0	0
Magnesium	ppm	ASTM D5185m		<b>71</b>	75	76
Calcium	ppm	ASTM D5185m		<b>2</b>	<1	2
Phosphorus	ppm	ASTM D5185m		<b>6</b>	4	4
Zinc	ppm	ASTM D5185m		<b>13</b>	4	3
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.539</b>	0.25	0.463
Visc @ 40°C	cSt	ASTM D445	32	<b>31.53</b>	31.9	31.2



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513

**Sample No.** : RP0029079

**Lab Number** : 06189324

**Unique Number** : 11046076

**Test Package** : PLANT

**Received** : 23 May 2024

**Tested** : 03 Jun 2024

**Diagnosed** : 03 Jun 2024 - Jonathan Hester

**ENERGY TRANSFER - TOLEDO**

2549 BROWN ROAD

OREGON, OH

US 43616

Contact: DARREN GRANT

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (419)389-7403

F: