WEAR CONTAMINATION FLUID CONDITION


NORMAL NORMAL NORMAL

Machine Id

TOL5_U2120 TOL5_U2120_SS2120

Main Bulk Fluid Tank

	GAL)						
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		RP0029039	RP0034048	RP0034030
	Sample Date		Client Info		15 May 2024	21 Feb 2024	16 Nov 202
	Machine Age	hrs	Client Info		5	5	5
	Oil Age	hrs	Client Info		5	5	5
	Filter Age	hrs	Client Info		0	0	0
	Oil Changed		Client Info		N/A	N/A	N/A
	Filter Changed		Client Info		N/A	N/A	N/A
	Sample Status				NORMAL	NORMAL	SEVERE
WEAR	Iron	ppm	ASTM D5185m		0	0	0
	Chromium	ppm	ASTM D5185m		0	0	0
All component wear rates are normal.	Nickel	ppm	ASTM D5185m		0	0	<1
	Titanium	ppm	ASTM D5185m		<1	0	0
	Silver	ppm	ASTM D5185m		<1	0	0
	Aluminum	ppm	ASTM D5185m		0	0	0
	Lead	ppm	ASTM D5185m		0	0	0
	Copper	ppm	ASTM D5185m		<1	0	0
	Tin	ppm	ASTM D5185m		0	0	0
	Vanadium	ppm	ASTM D5185m		<1	0	0
	White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
CONTAMINATION	Silicon	ppm	ASTM D5185m		2	2	2
The water content is negligible. There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185m	>20	1	0	<1
	Water	%	ASTM D6304		0.001	0.001	0.078
	ppm Water	ppm	ASTM D6304		8	10	780
	Silt	scalar	*Visual	NONE	NONE	NONE	NONE
	Debris	scalar	*Visual	NONE	NONE	NONE	▲ MODE
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
	Appearance	scalar	*Visual	NORML	NORML	NORML	NORM
	Odor	scalar	*Visual	NORML	NORML	NORML	NORM
	Emulsified Water	scalar	*Visual		NEG	NEG	0.2%
FLUID CONDITION	Sodium	ppm	ASTM D5185m		1	1	2
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.	Boron	ppm	ASTM D5185m		0	0	0
	Barium	ppm	ASTM D5185m		0	0	0
	Molybdenum	ppm	ASTM D5185m		0	0	0
	Manganese	ppm	ASTM D5185m		<1	0	0
	Magnesium	ppm	ASTM D5185m		0	<1	<1
	Calcium	ppm	ASTM D5185m		0	17	<1
	Phosphorus	ppm	ASTM D5185m		0	0	4
	Zinc	ppm	ASTM D5185m		0	0	0
	Acid Number (AN)	mg KOH/g	ASTM D8045		0.132	0.054	0.044
	Visc @ 40°C	cSt	ASTM D445	5.2	5.75		5.75
	Visc @ 100°C	cSt	ASTM D445	1.75	2.01		2.07
	Viscosity Index (VI)	Scale	ASTM D2270		163		191





Certificate L2367

Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : RP0029039 Lab Number : 06189665

Unique Number : 11046417

Received : 23 May 2024 **Tested** : 03 Jun 2024

Diagnosed

: 03 Jun 2024 - Jonathan Hester

Test Package : PLANT (Additional Tests: KV100, VI)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

T: (419)389-7403

Contact: DARREN GRANT

ENERGY TRANSFER - TOLEDO

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

2549 BROWN ROAD

OREGON, OH

US 43616

F: