CORROSION CONTAMINANTS COOLANT CONDITION

NORMAL NORMAL NORMAL


Machine Id

E-4 - RICHLAND CREEK

Component Coolant

{not provided} (--- GAL)

-11							
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
The fluid is suitable for further service.	Sample Number		Client Info		WC0944727	WC0880388	
	Sample Date		Client Info		20 May 2024	03 Jan 2024	
	Machine Age	hrs	Client Info		0	45477	
	Oil Age	hrs	Client Info		0	0	
	Oil Changed		Client Info		N/A	N/A	
	Sample Status				NORMAL	NORMAL	
CORROSION	Total Dissolved Solids				346.0	448.0	
	Coolant Appearance		*Visual	Clear	normal	normal	
CONTAMINANTS	Boiling Point	°C	WC Method		224		
There is no indication of any contamination in the coolant.	Specific Gravity		*ASTM D1298		1.063	1.065	
	рН	Scale 0-14	ASTM D1287		7.45	7.33	
	Nitrites	ppm	AP-053:2009		748	600	
	Reserve Alkalinity	Scale 0-20	*ASTM D1121				
	Percentage Glycol	%	ASTM D3321		46.7	47.9	
	Freezing Point	°F	ASTM D3321		-26	-28	
	Carboxylate				n/a	n/a	
	Coolant Color		*Visual		Pink	Red	





Certificate L2367

Laboratory Sample No.

Lab Number : 06189692 Unique Number : 11046444

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC0944727 Received **Tested**

Diagnosed

: 23 May 2024 : 29 May 2024

: 29 May 2024 - Doug Bogart

CUBE DISTRICT ENERGY - MAS GEORGIA LFG PLANT SITE 5691 S RICHLAND CREEK RD

BUFORD, GA US 30518

Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType, TAN Man, TBN) Contact: RYAN INGALLS ryan.ingalls@cubedistrictenergy.com

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: