

Machine Id E-2 - RICHLAND CREEK Component Coolant Fluid {not provided} (--- GAL)

RECO		


The fluid is suitable for further service.

CORROSION

CONTAMINANTS

There is no indication of any contamination in the coolant.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC0944725	WC0880390	
Sample Date		Client Info		20 May 2024	03 Jan 2024	
Machine Age	hrs	Client Info		51425	48994	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	NORMAL	
Total Dissolved Solids				319.5	367.0	
Coolant Appearance		*Visual	Clear	normal	normal	
Boiling Point	°C	WC Method		223		
Specific Gravity		*ASTM D1298		1.060	1.060	
рН	Scale 0-14	ASTM D1287		7.93	6.57	
Nitrites	ppm	AP-053:2009		748	600	
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		44.6	44.9	
Freezing Point	°F	ASTM D3321		-21	-21	
Carboxylate				n/a	n/a	
Coolant Color		*Visual		Pink	Pink	



Lab Number : 06189693 BUFORD, GA Tested : 11 Jun 2024 : 11 Jun 2024 - Doug Bogart US 30518 Unique Number : 11046445 Diagnosed Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType, TAN Man, TBN) Contact: RYAN INGALLS Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. ryan.ingalls@cubedistrictenergy.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: F: Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: RYAN INGALLS - CUBBUF Page 2 of 2