

WEAR
CONTAMINATION
FLUID CONDITION


NORMAL NORMAL

SH 46

SCHULZ 39818 - ROYAL THAI

Component Compressor

					.,		
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		UCS06190691	UCS06018273	
riosampie at the hext service interval to monitor.	Sample Date		Client Info		22 Mar 2024	12 Nov 2023	
	Machine Age	hrs	Client Info		2847	1775	
	Oil Age	hrs	Client Info		2847	1775	
	Filter Age	hrs	Client Info		1072	1475	
	Oil Changed		Client Info		Changed	Not Changd	
	Filter Changed		Client Info		Not Changd	Changed	
	Sample Status				NORMAL	NORMAL	
WEAD			AOTA DEADE			4	
WEAR	Iron	ppm	ASTM D5185m		<1	<1	
All component wear rates are normal.	Chromium	ppm	ASTM D5185m	>10	<1	<1	
	Nickel	ppm	ASTM D5185m		1	<1	
	Titanium	ppm	ASTM D5185m		<1	0	
	Silver	ppm	ASTM D5185m	0.5	1	0	
	Aluminum	ppm	ASTM D5185m		1	<1	
	Lead	ppm	ASTM D5185m		<1	<1	
	Copper	ppm	ASTM D5185m		1	1	
	Tin	ppm	ASTM D5185m	>15	<1	<1	
	Vanadium	ppm	ASTM D5185m		<1	0	
	White Metal	scalar	*Visual	NONE	NONE	HEAVY	
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
CONTAMINATION	Silicon	ppm	ASTM D5185m	>25	17	16	
There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185m	>20	1	<1	
	Water		WC Method	>0.1	NEG	NEG	
	Silt	scalar	*Visual	NONE	NONE	NONE	
	Debris	scalar	*Visual	NONE	NONE	NONE	
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
	Appearance	scalar	*Visual	NORML	NORML	NORML	
	Odor	scalar	*Visual	NORML	NORML	NORML	
	Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	
FLUID CONDITION	Codium	nnm	ACTM DE10Em			0	
	Sodium	ppm	ASTM D5185m		0	0	
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.	Barium	ppm	ASTM D5185m		0		
	Molybdenum	ppm	ASTM D5185m		<1	8 <1	
	,	ppm			<1		
	Manganese	ppm	ASTM D5185m		<1	<1	
	Magnesium	ppm	ASTM D5185m		<1	0	
	Calcium	ppm	ASTM D5185m		0 277	0	
	Phosphorus	ppm	ASTM D5185m ASTM D5185m		377	410	
	Zinc	ppm			3	0	
	Sulfur	ppm	ASTM D5185m		2084	2341	
	Acid Number (AN)	mg KOH/g	ASTM D8045	40.0	0.087	0.084	
Report Id: LICELIMCD [WLISCAR] 06190691 (Generated: 05/29/2024 07:22:43) Rev: 1	Visc @ 40°C	cSt	ASTM D445		46.7	49.4	







Certificate L2367

Laboratory Sample No.

Lab Number : 06190691

: UCS06190691 Unique Number : 11047443 Test Package : IND 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 24 May 2024 **Tested**

Diagnosed

: 28 May 2024 : 28 May 2024 - Wes Davis

08.0 PG 0.60

> 0.20 0.00

> > MCDONOUGH, GA US 30252

Contact: RONNY MINNIX elitecompressed@gmail.com T: (770)898-9594

ELITE COMPRESSED AIR SYSTEMS INC

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: RONNY MINNIX - UCELIMCD