**CORROSION CONTAMINANTS COOLANT CONDITION** 


**SEVERE NORMAL NORMAL** 

THUNDER SPIRIT [200009532]

02WEA84039 - GEN (S/N 72802187616)
Component
Coolant

INTERCOOL NEF-55 AA (-

RECOMMENDATION	<b>-</b> .						
	Test	UOM	Method	Limit/Abn	Current	History1	History2
We recommend drain/flush system, and refill with 50/50 antifreeze water mixture.	Sample Number		Client Info		NX015520		
	Sample Date		Client Info		01 May 2024		
	Machine Age	hrs	Client Info		58580		
	Oil Age	hrs	Client Info		0		
	Oil Changed		Client Info		N/A		
	Sample Status				SEVERE		
CORROSION	Iron	ppm	ASTM D6130	>15	<b>164</b>		
Metal levels are high indicating corrosion in the cooling system.	Aluminum	ppm	ASTM D6130	>10	2		
	Copper	ppm	ASTM D6130	>10	1		
	Lead	ppm	ASTM D6130	>10	0		
	Tin	ppm	ASTM D6130	>10	0		
	Zinc	ppm	ASTM D6130	>10	16		
CONTAMINANTS	Calcium	ppm	ASTM D6130		<1		
There is no indication of any contamination in the coolant.	Chlorine	ppm	ASTM D6130		10		
	Magnesium	ppm	ASTM D6130		2		
	Total Dissolved Solids	1-1-			226.5		
	Coolant Appearance		*Visual	Clear	normal		
COOLANT CONDITION	Dalling Daint		MO Mathad		007		
Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.	Boiling Point	°C	WC Method		227		
	Specific Gravity pH	Scale 0-14	*ASTM D1298 ASTM D1287		1.074		
	Nitrites		AP-053:2009		9.21 712		
	Reserve Alkalinity	ppm Scale 0-20	*ASTM D1121				
	Percentage Glycol		ASTM D3321		 55.4		
	Freezing Point		ASTM D3321		-47		
	Carboxylate		AOTIVI DOOLT		n/a		
	Silicon	ppm	ASTM D6130		95		
	Phosphorus	ppm	ASTM D6130		1367		
	Boron	ppm	ASTM D6130		290		
	Molybdenum	ppm	ASTM D6130		287		
	Sodium	ppm	ASTM D6130		970		
	Potassium	ppm	ASTM D6130		4005		
	Coolant Color	r r	*Visual		Orange		





Certificate L2367

Report Id: NORDEX [WUSCAR] 06190893 (Generated: 05/30/2024 15:19:55) Rev: 1

Laboratory Sample No.

Lab Number : 06190893

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : NX015520

Received Unique Number : 11047645

: 24 May 2024 **Tested** Diagnosed Test Package : COOL- ( Additional Tests: BoilingPoint, COOL, GlycolType, ICP )

: 30 May 2024 : 30 May 2024 - Jonathan Hester

400

**NORDEX USA - Chicago** 300 SOUTH WACKER DRIVE, SUITE 1500

CHICAGO, IL US 60606 Contact: DEREK BRACKEL

F: (312)386-7102

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. DBRACKEL@nordex-online.com T: (701)209-0326