
WEAR CONTAMINATION FLUID CONDITION

NORMAL NORMAL NORMAL

Machine Id

IDENTIFY LUBE
Component
New (Unused) Oil

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
TESSIMILIBATION	Sample Number	OOW	Client Info	LITTIO/ NOT	UCS06191174		
Resample at the next service interval to monitor. Please contact	Sample Date		Client Info		27 May 2024		
Ultrachem for appropriate replacement oil.	Machine Age	hrs	Client Info		0		
	Oil Age	hrs	Client Info		0		
	Filter Age	hrs	Client Info		0		
	Oil Changed	1110	Client Info		N/A		
	Filter Changed		Client Info		N/A		
	Sample Status		Onone into		NORMAL		
WEAR  All component wear rates are normal.	Iron	ppm	ASTM D5185m	>5	<1		
	Chromium	ppm	ASTM D5185m	>5	<1		
	Nickel	ppm	ASTM D5185m	>5	<1		
	Titanium	ppm	ASTM D5185m		<1		
	Silver	ppm	ASTM D5185m	>5	1		
	Aluminum	ppm	ASTM D5185m	>5	1		
	Lead	ppm	ASTM D5185m	>5	<1		
	Copper	ppm	ASTM D5185m	>5	1		
	Tin	ppm	ASTM D5185m	>5	<1		
	Vanadium	ppm	ASTM D5185m		<1		
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
CONTAMINATION	Silicon	nnm	ASTM D5185m	>15	4		
CONTAININATION	Potassium	ppm	ASTM D5185m		3		
There is no indication of any contamination in the oil.	Water	ppm	WC Method	>20	NEG		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
	Appearance	scalar	*Visual	NORML	NORML		
	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	NOTHIVIE	NEG		
			• • • • • • • • • • • • • • • • • • •				
FLUID CONDITION	Sodium	ppm	ASTM D5185m		0		
Viscosity of sample indicates oil is within ISO 46 range. FTIR of sample indicates oil is a synthetic ester. The AN level is acceptable for this fluid.	Boron	ppm	ASTM D5185m		0		
	Barium	ppm	ASTM D5185m		<1		
	Molybdenum	ppm	ASTM D5185m		<1		
	Manganese	ppm	ASTM D5185m		<1		
	Magnesium	ppm	ASTM D5185m		0		
	Calcium	ppm	ASTM D5185m		0		
	Phosphorus	ppm	ASTM D5185m		375		
	Zinc	ppm	ASTM D5185m		6		
	Sulfur	ppm	ASTM D5185m		1408		
	Acid Number (AN)	mg KOH/g	ASTM D8045		0.65		
	Visc @ 40°C	cSt	ASTM D445		46.3		
	Visc @ 100°C	cSt	ASTM D445		8.03		
	Viscosity Index (VI)	Scale	ASTM D2270		146		







Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : UCS06191174 Lab Number : 06191174

Unique Number: 11047926

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Received **Tested** Diagnosed

: 24 May 2024 : 04 Jun 2024

: 04 Jun 2024 - Doug Bogart

KOMPRESSED AIR OF DELEWARE

144 QUIQLEY BLVD NEW CASTLE, DE US 19720

Test Package : IND 2 ( Additional Tests: FT-IR, ICP-NewOil, KV100, PrtCount, VI ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

Contact: BEN SPENCE BENSPENCE@KOMPRESSEDAIR.COM T: (302)322-4900

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: BEN SPENCE - UCKOMNEW

F: (302)322-8105