

NOT GIVEN Machine Id SULLAIR 201904220026 - TULSA CEMENT SCALE HOUSE QUARRY Component Compressor

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.	Sample Number		Client Info		UCH06192923	UCH06162035	UCH05934444
	Sample Date		Client Info		22 May 2024	18 Apr 2024	10 Aug 2023
	Machine Age	hrs	Client Info		35959	35509	28074
	Oil Age	hrs	Client Info		8000	8000	8000
	Filter Age	hrs	Client Info		8000	8000	0
	Oil Changed		Client Info		Changed	Changed	Changed
	Filter Changed		Client Info		Changed	Changed	Changed
	Sample Status				NORMAL	NORMAL	ATTENTION
WEAR	Iron	ppm	ASTM D5185m	>50	5	0	3
	Chromium	ppm	ASTM D5185m		0	<1	0
All component wear rates are normal.	Nickel	ppm	ASTM D5185m		<1	0	0
	Titanium	ppm	ASTM D5185m		<1	<1	0
	Silver	ppm	ASTM D5185m		<1	<1	<1
	Aluminum	ppm	ASTM D5185m	>25	6	2	2
	Lead	ppm	ASTM D5185m		1	1	<1
	Copper	ppm	ASTM D5185m	>50	<1	<1	36
	Tin	ppm	ASTM D5185m	>15	<1	1	2
	Vanadium	ppm	ASTM D5185m		0	<1	0
	White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
CONTAMINATION	Ciliaaa				47	4	4
CONTAMINATION	Silicon	ppm		>25	17	4	4
Moderate concentration of visible dirt/debris present in the oil.	Potassium	ppm	ASTM D5185m		6 NEC	5 NEG	2 NEG
	Water Silt	agalar	WC Method *Visual	>0.8 NONE	NEG NONE	NONE	MODER
	Debris	scalar scalar	*Visual	NONE	MODER	NONE	MODER
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
	Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
	Odor	scalar	*Visual	NORML	NORML	NORML	NORML
	Emulsified Water	scalar	*Visual	>0.8	NEG	NEG	NEG
FLUID CONDITION	Sodium	ppm	ASTM D5185m		16	4	0
The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.	Boron	ppm	ASTM D5185m		0	0	7
	Barium	ppm	ASTM D5185m		467	68	113
	Maluhaanum	ppm	ASTM D5185m	10	0	0	1
	Molybdenum		107110				
	Manganese	ppm	ASTM D5185m	-	<1	0	0
	Manganese Magnesium	ppm	ASTM D5185m		4	1	2
	Manganese Magnesium Calcium	ppm ppm	ASTM D5185m ASTM D5185m	10	4 90	1	2
	Manganese Magnesium Calcium Phosphorus	ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m	10 250	4 90 9	1 1 36	2 1351 522
	Manganese Magnesium Calcium	ppm ppm	ASTM D5185m ASTM D5185m	10 250 100	4 90	1	2

Acid Number (AN) mg KOH/g ASTM D8045

ASTM D445 46

Visc @ 40°C cSt

Contact/Location: ASHLEY PIGUET - UCGRECLA

0.39


40.1

0.21

47.5

75.5

0.64



Sample No. : UCH06192923 Received 11974 E 530 RD : 28 May 2024 Lab Number : 06192923 Tested CLAREMORE, OK : 30 May 2024 Unique Number : 11049675 Diagnosed : 30 May 2024 - Sean Felton US 74019 Test Package : IND 2 Contact: ASHLEY PIGUET Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. ashley@gccs.us.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: (918)906-6343 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: