



OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	ABNORMAL
FLUID CONDITION	NORMAL

Area
[75202654]
 Machine Id
MATTEI ERC 1022
 Component
Compressor
 Fluid
ROTOROIL 8000 (3 GAL)

RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

WEAR

All component wear rates are normal.









CONTAMINATION

Elemental level of silicon (Si) above normal. The water content is negligible.

FLUID CONDITION

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		AN35908	AN013392	---
Sample Date		Client Info		09 Feb 2024	20 Feb 2008	---
Machine Age	hrs	Client Info		0	6220	---
Oil Age	hrs	Client Info		0	0	---
Filter Age	hrs	Client Info		0	0	---
Oil Changed		Client Info		N/A	Changed	---
Filter Changed		Client Info		N/A	N/A	---
Sample Status				ABNORMAL	NORMAL	---
Iron	ppm	ASTM D5185m	>50	8	45	---
Chromium	ppm	ASTM D5185m	>10	<1	<1	---
Nickel	ppm	ASTM D5185m		<1	0	---
Titanium	ppm	ASTM D5185m		<1	<1	---
Silver	ppm	ASTM D5185m		1	0	---
Aluminum	ppm	ASTM D5185m	>25	2	4	---
Lead	ppm	ASTM D5185m	>25	<1	3	---
Copper	ppm	ASTM D5185m	>50	1	1	---
Tin	ppm	ASTM D5185m	>15	<1	0	---
Vanadium	ppm	ASTM D5185m		<1	0	---
White Metal	scalar	*Visual	NONE	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	---
Silicon	ppm	ASTM D5185m	>25	▲ 31	15	---
Potassium	ppm	ASTM D5185m	>20	3	0	---
Water	%	ASTM D6304	>0.1	0.029	0.090	---
ppm Water	ppm	ASTM D6304	>1000	300	---	---
Silt	scalar	*Visual	NONE	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	LIGHT	---
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	---
Sodium	ppm	ASTM D5185m		<1	45	---
Boron	ppm	ASTM D5185m		0	<1	---
Barium	ppm	ASTM D5185m		0	<1	---
Molybdenum	ppm	ASTM D5185m		<1	<1	---
Manganese	ppm	ASTM D5185m		<1	<1	---
Magnesium	ppm	ASTM D5185m		4	12	---
Calcium	ppm	ASTM D5185m		0	8	---
Phosphorus	ppm	ASTM D5185m	884	913	846	---
Zinc	ppm	ASTM D5185m		2	197	---
Sulfur	ppm	ASTM D5185m		0	67	---
Acid Number (AN)	mg KOH/g	ASTM D8045	0.1	0.25	0.489	---
Visc @ 40°C	cSt	ASTM D445	87.69	60.5	89.17	---



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : AN35908
Lab Number : 06194057
Unique Number : 11056180
Test Package : IND 2

Received : 29 May 2024
Tested : 31 May 2024
Diagnosed : 31 May 2024 - Jonathan Hester

MATTEI COMPRESSORS--OEM
 9635 LIBERTY ROAD, SUITE E
 RANDALLSTOWN, MD
 US 21133

Contact: MARTY WARD
 jward@matteicomp.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (410)521-7020
 F: (410)521-7024