WEAR
CONTAMINATION
FLUID CONDITION


NORMAL NORMAL NORMAL

NOT GIVEN

## **SULLIVAN PALATEK 23CE003885 - NARM**

Component Compressor

					.,		
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor. The fluid was not specified, however, a fluid match indicates that this fluid is (GENERIC) COMPRESSOR OIL (PAG) ISO 46. Please confirm.	Sample Number		Client Info		UCS06194170		
	Sample Date		Client Info		19 Apr 2024		
	Machine Age	hrs	Client Info		2676		
	Oil Age	hrs	Client Info		0		
	Filter Age	hrs	Client Info		0		
	Oil Changed		Client Info		Not Changd		
	Filter Changed		Client Info		Changed		
	Sample Status				NORMAL		
WEAR	lvon		ASTM D5185m	. 50			
WEAN	Iron	ppm			<1		
All component wear rates are normal.	Chromium	ppm	ASTM D5185m	>10	<1		
	Nickel	ppm	ASTM D5185m		<1		
	Titanium	ppm	ASTM D5185m		<1		
	Silver	ppm	ASTM D5185m	. 05	1		
	Aluminum	ppm	ASTM D5185m		1		
	Lead	ppm	ASTM D5185m		<1		
	Copper	ppm	ASTM D5185m		1		
	Tin	ppm	ASTM D5185m	>15	<1		
	Vanadium White Metal	ppm	ASTM D5185m	NONE	<1 NONE		
		scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	INOINE		
CONTAMINATION	Silicon	ppm	ASTM D5185m	>25	3		
There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185m	>20	1		
	Water		WC Method	>0.8	NEG		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
	Appearance	scalar	*Visual	NORML	NORML		
	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.8	NEG		
FLUID CONDITION	Sodium	ppm	ASTM D5185m		2		
	Boron	ppm	ASTM D5185m	2	0		
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.	Barium	ppm	ASTM D5185m	525	266		
	Molybdenum	ppm	ASTM D5185m		<1		
	Manganese	ppm	ASTM D5185m		<1		
	Magnesium	ppm	ASTM D5185m	5	0		
	Calcium	ppm	ASTM D5185m		0		
	Phosphorus	ppm	ASTM D5185m		262		
	Zinc	ppm	ASTM D5185m		0		
	Sulfur	ppm	ASTM D5185m		722		
	Acid Number (AN)	mg KOH/g	ASTM D8045		0.063		
	Acid Nulliber (AIN)				0.000		
	Visc @ 40°C	cSt	ASTM D445	46	43.8		







Certificate L2367

Laboratory Sample No.

**Lab Number** : 06194170 Unique Number : 11056293 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : UCS06194170 Received : 29 May 2024 **Tested** 

: 30 May 2024 Diagnosed : 30 May 2024 - Wes Davis

₽ 0.04 흩 0.03 0.02

> 0.0 0.01 0.00

> > COMPRESSION LEASING SERVICES, INC 1935 N LOOP AVENUE & 1925 N LOOP AV

CASPER, WY US 82601 Contact: ANGIE MANZANAREZ

To discuss this sample report, contact Customer Service at 1-800-237-1369.

amanz@cls-inc.com T: (307)265-3242 F: (307)265-3221

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)