



WEAR	NORMAL
CONTAMINATION	ABNORMAL
FLUID CONDITION	NORMAL

Machine Id
KAESER 1076 - BAKERY EXPRESS

Component
Compressor

Fluid
QUINCY QUINSYN F (5 GAL)

RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

WEAR

All component wear rates are normal.











CONTAMINATION

There is a high amount of particulates present in the oil.

FLUID CONDITION

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		QUC0000901	QUC0000732	---
Sample Date		Client Info		03 Jun 2024	14 Mar 2024	---
Machine Age	hrs	Client Info		75835	73322	---
Oil Age	hrs	Client Info		0	0	---
Filter Age	hrs	Client Info		0	0	---
Oil Changed		Client Info		Changed	Changed	---
Filter Changed		Client Info		Changed	Changed	---
Sample Status				ABNORMAL	ABNORMAL	---
Iron	ppm	ASTM D5185m	>50	0	0	---
Chromium	ppm	ASTM D5185m	>10	0	0	---
Nickel	ppm	ASTM D5185m	>3	0	0	---
Titanium	ppm	ASTM D5185m	>3	0	0	---
Silver	ppm	ASTM D5185m	>2	0	0	---
Aluminum	ppm	ASTM D5185m	>10	<1	<1	---
Lead	ppm	ASTM D5185m	>10	0	0	---
Copper	ppm	ASTM D5185m	>50	11	5	---
Tin	ppm	ASTM D5185m	>10	0	0	---
Vanadium	ppm	ASTM D5185m		0	<1	---
White Metal	scalar	*Visual	NONE	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	---
Silicon	ppm	ASTM D5185m	>25	<1	<1	---
Potassium	ppm	ASTM D5185m	>20	0	<1	---
Water	%	ASTM D6304	>0.05	0.003	0.007	---
ppm Water	ppm	ASTM D6304	>500	27	73	---
Particles >4µm		ASTM D7647		11816	23302	---
Particles >6µm		ASTM D7647	>1300	▲ 3788	▲ 7143	---
Particles >14µm		ASTM D7647	>80	▲ 198	▲ 556	---
Particles >21µm		ASTM D7647	>20	● 32	▲ 122	---
Particles >38µm		ASTM D7647	>4	1	2	---
Particles >71µm		ASTM D7647	>3	0	0	---
Oil Cleanliness		ISO 4406 (c)	>-/17/13	▲ 21/19/15	▲ 22/20/16	---
Silt	scalar	*Visual	NONE	NONE	NONE	---
Debris	scalar	*Visual	NONE	LIGHT	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	---
Sodium	ppm	ASTM D5185m		<1	2	---
Boron	ppm	ASTM D5185m		0	0	---
Barium	ppm	ASTM D5185m		0	<1	---
Molybdenum	ppm	ASTM D5185m		0	0	---
Manganese	ppm	ASTM D5185m		0	0	---
Magnesium	ppm	ASTM D5185m		0	0	---
Calcium	ppm	ASTM D5185m		0	0	---
Phosphorus	ppm	ASTM D5185m		141	181	---
Zinc	ppm	ASTM D5185m		162	104	---
Sulfur	ppm	ASTM D5185m		25	35	---
Acid Number (AN)	mg KOH/g	ASTM D8045	.10	0.39	0.52	---
Visc @ 40°C	cSt	ASTM D445	42	43.5	43.5	---
Visc @ 100°C	cSt	ASTM D445	7.3	7.5	7.1	---
Viscosity Index (VI)	Scale	ASTM D2270	135	139	123	---



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : QUC0000901 **Received** : 14 Jun 2024
Lab Number : 06210104 **Tested** : 17 Jun 2024
Unique Number : 11082968 **Diagnosed** : 17 Jun 2024 - Angela Borella
Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

QUALITY COMPRESSOR

4428 CR 616
 ALVARADO, TX
 US 76009
 Contact: SEAN
 SEAN@QCOMPRESSOR.COM
 T: (817)822-1333
 F: