



WEAR	NORMAL
CONTAMINATION	ABNORMAL
FLUID CONDITION	ABNORMAL

Machine Id
PALATEK 11B052 - KEMOSABE
 Component
Compressor
 Fluid
QUINCY QUINSYN (--- GAL)

RECOMMENDATION

Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

WEAR

All component wear rates are normal.

CONTAMINATION

There is a high amount of visible silt present in the sample. Free water present.

FLUID CONDITION

The oil viscosity is higher than normal. The AN level is acceptable for this fluid. The oil is no longer serviceable due to the presence of contaminants.


Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		QUC0000657	TO90002089	---
Sample Date		Client Info		31 May 2024	17 Feb 2022	---
Machine Age	hrs	Client Info		2065	6926	---
Oil Age	hrs	Client Info		0	0	---
Filter Age	hrs	Client Info		0	0	---
Oil Changed		Client Info		Changed	Not Changd	---
Filter Changed		Client Info		Changed	Changed	---
Sample Status				ABNORMAL	ABNORMAL	---

Iron	ppm	ASTM D5185m	>50	20	8	---
Chromium	ppm	ASTM D5185m	>10	0	0	---
Nickel	ppm	ASTM D5185m		0	0	---
Titanium	ppm	ASTM D5185m		0	0	---
Silver	ppm	ASTM D5185m		0	0	---
Aluminum	ppm	ASTM D5185m	>25	0	1	---
Lead	ppm	ASTM D5185m	>25	0	0	---
Copper	ppm	ASTM D5185m	>50	<1	<1	---
Tin	ppm	ASTM D5185m	>15	0	0	---
Vanadium	ppm	ASTM D5185m		<1	0	---
White Metal	scalar	*Visual	NONE	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	---


Silicon	ppm	ASTM D5185m	>25	<1	1	---
Potassium	ppm	ASTM D5185m	>20	0	<1	---
Water	%	ASTM D6304	>0.1	0.098	0.004	---
ppm Water	ppm	ASTM D6304	>1000	980	47.7	---
Silt	scalar	*Visual	NONE	HEAVY	NONE	---
Debris	scalar	*Visual	NONE	NONE	MODER	---
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	---
Appearance	scalar	*Visual	NORML	LAYRD	NORML	---
Odor	scalar	*Visual	NORML	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.1	0.2%	NEG	---

Sodium	ppm	ASTM D5185m		3	11	---
Boron	ppm	ASTM D5185m		0	0	---
Barium	ppm	ASTM D5185m		0	0	---
Molybdenum	ppm	ASTM D5185m		0	0	---
Manganese	ppm	ASTM D5185m		0	<1	---
Magnesium	ppm	ASTM D5185m		0	<1	---
Calcium	ppm	ASTM D5185m		0	10	---
Phosphorus	ppm	ASTM D5185m		155	128	---
Zinc	ppm	ASTM D5185m		191	44	---
Sulfur	ppm	ASTM D5185m		933	647	---
Acid Number (AN)	mg KOH/g	ASTM D8045	.10	0.39	0.13	---
Visc @ 40°C	cSt	ASTM D445	44.6	53.5	45.5	---
Visc @ 100°C	cSt	ASTM D445	7.8	8.1	7.6	---
Viscosity Index (VI)	Scale	ASTM D2270	132	120	134	---


▲ Viscosity @ 40°C




Ferrous Alloys




Acid Number




Non-ferrous Metals




Water (KF)




Viscosity @ 100°C



▲ Viscosity @ 40°C



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : QUC0000657 **Received** : 14 Jun 2024
Lab Number : 06210124 **Tested** : 18 Jun 2024
Unique Number : 11082988 **Diagnosed** : 18 Jun 2024 - Angela Borella
Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)

QUALITY COMPRESSOR
 4428 CR 616
 ALVARADO, TX
 US 76009
 Contact: SEAN
 SEAN@QCOMPRESSOR.COM
 T: (817)822-1333
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)