

WEAR NORMAL CONTAMINATION NORMAL FLUID CONDITION NORMAL

PALEXTRA 44 Machine Id SULLIVAN PALATEK 20EE001205 - SMITH SEED SERVICES Component Compressor

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		UCS06210260	UCS06059368	UCS06059363
	Sample Date		Client Info		02 Jan 2024	02 Nov 2023	07 Sep 2023
	Machine Age	hrs	Client Info		17353	16122	15692
	Oil Age	hrs	Client Info		1231	3974	3544
	Filter Age	hrs	Client Info		1231	1164	734
	Oil Changed		Client Info		Not Changd	Changed	Not Changd
	Filter Changed		Client Info		Changed	Changed	Changed
	Sample Status				NORMAL	NORMAL	NORMAL
WEAR	Iron	ppm	ASTM D5185m	>50	<1	0	0
	Chromium	ppm	ASTM D5185m		0	0	0
All component wear rates are normal.	Nickel	ppm	ASTM D5185m		0	0	0
	Titanium	ppm	ASTM D5185m		0	0	0
	Silver	ppm	ASTM D5185m		0	0	0
	Aluminum	ppm	ASTM D5185m	>25	<1	0	0
	Lead	ppm	ASTM D5185m	>25	0	0	0
	Copper	ppm	ASTM D5185m	>50	2	0	0
	Tin	ppm	ASTM D5185m	>15	<1	0	0
	Vanadium	ppm	ASTM D5185m		0	0	0
	White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
CONTAMINATION	Silicon		ASTM D5185m	. 25	2	2	<1
	Potassium	ppm	ASTM D5185m		2	2 0	0
There is no indication of any contamination in the oil.	Water	ppm	WC Method		3 NEG	NEG	NEG
	Silt	scalar	*Visual	NONE	NONE	LIGHT	NONE
	Debris	scalar	*Visual	NONE	LIGHT	NONE	NONE
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
	Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
	Odor	scalar	*Visual	NORML	NORML	NORML	NORML
	Emulsified Water		*Visual	>0.1	NEG	NEG	NEG
					·····		
FLUID CONDITION	Sodium	ppm	ASTM D5185m	0	<1	0	0
The AN level is acceptable for this fluid. The condition of the oil is	Boron	ppm	ASTM D5185m		<1	0	0
suitable for further service.	Barium	ppm	ASTM D5185m		0	0	0
	Molybdenum	ppm	ASTM D5185m		<1	0	0
	Manganese Magnesium	ppm	ASTM D5185m ASTM D5185m		<1 0	0	0
	Calcium	ppm ppm	ASTM D5185m		0	0	0
	Phosphorus		ASTM D5185m		544	659	477
	Zinc	ppm	ASTM D5185m		0	0	0
	Sulfur	ppm ppm	ASTM D5185m		731	882	331
	Acid Number (AN)				0.15	0.093	0.22
		ing itori/g	//011010040	0.100	0.15	0.000	0.22


Contact/Location: CRAIG WORLEY - UCNORALB

42.6

42.5

Visc @ 40°C cSt ASTM D445 44.62

44.1



Diagnosed Test Package : IND 2 Contact: CRAIG WORLEY Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. service@nwcompressor.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: CRAIG WORLEY - UCNORALB Page 2 of 2

T: (541)752-5366

F: (541)752-4716