



WEAR	<b>NORMAL</b>
CONTAMINATION	<b>NORMAL</b>
FLUID CONDITION	<b>NORMAL</b>

Area  
**MARY K CAVARRA**  
Machine Id  
**[MARY K CAVARRA] 004 579878-4**  
Component  
**Port Reduction Gear**  
Fluid  
**CHEVRON MEROPA 320 (--- GAL)**

**RECOMMENDATION**

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>MW0051229</b>	MW0061289	MW0061294
Sample Date		Client Info		<b>01 Jun 2024</b>	01 Dec 2023	01 Nov 2023
Machine Age	hrs	Client Info		<b>78433</b>	78184	77466
Oil Age	hrs	Client Info		<b>191</b>	78184	77466
Filter Age	hrs	Client Info		<b>0</b>	78184	0
Oil Changed		Client Info		<b>N/A</b>	Not Changd	N/A
Filter Changed		Client Info		<b>N/A</b>	None	N/A
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL

**WEAR**

All component wear rates are normal.

Iron	ppm	ASTM D5185m	>150	<b>26</b>	59	52
Chromium	ppm	ASTM D5185m	>10	<b>&lt;1</b>	<1	0
Nickel	ppm	ASTM D5185m	>10	<b>&lt;1</b>	<1	0
Titanium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	0
Silver	ppm	ASTM D5185m		<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>25	<b>2</b>	2	1
Lead	ppm	ASTM D5185m	>100	<b>0</b>	<1	0
Copper	ppm	ASTM D5185m	>50	<b>3</b>	6	5
Tin	ppm	ASTM D5185m	>10	<b>0</b>	<1	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE

**CONTAMINATION**






There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185m	>50	<b>8</b>	<1	0
Potassium	ppm	ASTM D5185m	>20	<b>1</b>	3	0
Water		WC Method	>0.1	<b>NEG</b>	NEG	NEG
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	<b>NEG</b>	NEG	NEG

**FLUID CONDITION**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185m		<b>&lt;1</b>	5	5
Boron	ppm	ASTM D5185m	20	<b>11</b>	4	<1
Barium	ppm	ASTM D5185m		<b>1</b>	<1	0
Molybdenum	ppm	ASTM D5185m	0	<b>&lt;1</b>	2	<1
Manganese	ppm	ASTM D5185m		<b>0</b>	1	<1
Magnesium	ppm	ASTM D5185m		<b>&lt;1</b>	2	0
Calcium	ppm	ASTM D5185m	25	<b>21</b>	27	24
Phosphorus	ppm	ASTM D5185m	235	<b>316</b>	260	211
Zinc	ppm	ASTM D5185m		<b>10</b>	4	0
Sulfur	ppm	ASTM D5185m		<b>5624</b>	2854	2577
Acid Number (AN)	mg KOH/g	ASTM D8045	0.56	<b>0.83</b>	0.91	0.89
Visc @ 40°C	cSt	ASTM D445	304	<b>315</b>	335	329



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513

**Sample No.** : MW0051229

**Lab Number** : 06210859

**Unique Number** : 11083723

**Test Package** : MAR 2

**Received** : 14 Jun 2024

**Tested** : 18 Jun 2024

**Diagnosed** : 18 Jun 2024 - Wes Davis

**INGRAM BARGE**

900 S 3RD ST

PADUCAH, KY

US 42003

Contact: DALE MORIE

dale.morie@ingrambarga.com

T: (270)415-4467

F: (615)695-3697

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)