

ROTO XTEND ATLAS COPCO ITJ468003 - CALIBER COLLISION 1747 Component Compressor

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		UCH06211796	UCH0000599	UCH05780199
	Sample Date		Client Info		10 Jun 2024	22 May 2024	27 Feb 2023
	Machine Age	hrs	Client Info		7913	7615	4385
	Oil Age	hrs	Client Info		298	0	4385
	Filter Age	hrs	Client Info		298	0	4385
	Oil Changed		Client Info		Changed	Changed	Changed
	Filter Changed		Client Info		Changed	Changed	Changed
	Sample Status				NORMAL	NORMAL	NORMAL
WEAR	Iron	ppm	ASTM D5185m	>50	2	2	<1
All component wear rates are normal.	Chromium	ppm	ASTM D5185m	>5	0	0	0
	Nickel	ppm	ASTM D5185m		<1	2	5
	Titanium	ppm	ASTM D5185m		<1	0	0
	Silver	ppm	ASTM D5185m		0	0	0
	Aluminum	ppm	ASTM D5185m	>15	0	<1	<1
	Lead	ppm	ASTM D5185m	>65	0	0	0
	Copper	ppm	ASTM D5185m	>65	<1	<1	<1
	Tin	ppm	ASTM D5185m	>10	0	<1	0
	Vanadium	ppm	ASTM D5185m		<1	0	0
	White Metal	scalar	*Visual	NONE	NONE	NONE	LIGHT
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
CONTAMINATION	Silicon	ppm	ASTM D5185m	>35	2	5	12
There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185m	>20	0	1	0
	Water		WC Method	>0.1	NEG	NEG	NEG
	Silt	scalar	*Visual	NONE	NONE	NONE	NONE
	Debris	scalar	*Visual	NONE	NONE	NONE	NONE
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
	Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
	Odor	scalar	*Visual	NORML	NORML	NORML	NORML
	Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
FLUID CONDITION	Sodium	ppm	ASTM D5185m		4	2	<1
The AN level is acceptable for this fluid. The condition of the oil is	Boron	ppm	ASTM D5185m		0	0	0
suitable for further service.	Barium	ppm	ASTM D5185m		0	9	0
	Molybdenum	ppm	ASTM D5185m		0	0	0
	Manganese	ppm	ASTM D5185m		<1	<1	0
	Magnesium	ppm	ASTM D5185m		0	0	0
	Calcium	ppm	ASTM D5185m		0	0	0
	Phosphorus	ppm	ASTM D5185m		55	33	29
	Zinc	ppm	ASTM D5185m		137	78	41
	Sulfur	ppm	ASTM D5185m		174	173	154

46.4 Contact/Location: RANDY BEAUCHAMP - UCTATRIC

0.18

0.08


47.6

Acid Number (AN) mg KOH/g ASTM D8045 0.14

Visc @ 40°C cSt ASTM D445 46

0.07

46.2



Lab Number : 06211796 Tested : 18 Jun 2024 RICHMOND, VA Unique Number : 11084660 Diagnosed : 18 Jun 2024 - Wes Davis US 23237 Test Package : IND 2 Contact: RANDY BEAUCHAMP Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. randy.beauchamp@tate.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: (757)214-6541 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (804)743-0415

Contact/Location: RANDY BEAUCHAMP - UCTATRIC Page 2 of 2