**WEAR** CONTAMINATION **FLUID CONDITION** 

**NORMAL ABNORMAL NORMAL** 

Machine Id

## MATTEI 10008980-2019

Compressor

ROTOROIL 8000F2 (2 QTS)					-,		
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
No corrective action is recommended at this time. Resample at the next service interval to monitor.	Sample Number		Client Info		AN37652		
	Sample Date		Client Info		03 May 2024		
	Machine Age	hrs	Client Info		4080		
	Oil Age	hrs	Client Info		0		
	Filter Age	hrs	Client Info		0		
	Oil Changed		Client Info		Changed		
	Filter Changed		Client Info		N/A		
	Sample Status				ABNORMAL		
WEAR	Iron	ppm	ASTM D5185m	>50	7		
	Chromium	ppm	ASTM D5185m		0		
All component wear rates are normal.	Nickel	ppm	ASTM D5185m	>10	0		
	Titanium	ppm	ASTM D5185m		0		
	Silver	ppm	ASTM D5185m		0		
	Aluminum	ppm	ASTM D5185m	>25	0		
	Lead	ppm	ASTM D5185m		0		
	Copper	ppm	ASTM D5185m	>50	0		
	Tin	ppm	ASTM D5185m		0		
	Vanadium	ppm	ASTM D5185m		0		
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
DON'T A BUN A TION							
CONTAMINATION  Elemental level of silicon (Si) above normal. The water content is negligible.	Silicon	ppm	ASTM D5185m		<u>^</u> 61		
	Potassium	ppm	ASTM D5185m		0		
	Water	%	ASTM D6304	>0.1	0.068		
	ppm Water	ppm	ASTM D6304		681 NONE		
	Silt	scalar	*Visual	NONE	NONE		
	Debris Sand/Dirt	scalar	*Visual	NONE	NONE NONE		
		scalar	*Visual	NONE			
	Appearance Odor	scalar scalar	*Visual *Visual	NORML NORML	NORML NORML		
	Emulsified Water		*Visual	>0.1	NEG		
	Lindishica Water		Viouai	20.1			
FLUID CONDITION	Sodium	ppm	ASTM D5185m		8		
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.	Boron	ppm	ASTM D5185m		0		
	Barium	ppm	ASTM D5185m		0		
	Molybdenum	ppm	ASTM D5185m		0		
	Manganese	ppm	ASTM D5185m		0		
	Magnesium	ppm	ASTM D5185m		0		
	Calcium	ppm	ASTM D5185m		0		
	Phosphorus	ppm	ASTM D5185m		975		
	Zinc	ppm	ASTM D5185m		12		
	Sulfur	ppm	ASTM D5185m		126		
	Acid Number (AN)	mg KOH/g	ASTM D8045		0.077		
Report Id: MATTELIWUSCARI 06213550 (Generated: 06/23/2024 04:08:08) Rev: 1	Visc @ 40°C	cSt	ASTM D445		74.6		







Certificate L2367

Laboratory Sample No.

: AN37652 Lab Number : 06213550 Unique Number : 11086414 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 18 Jun 2024 **Tested** : 20 Jun 2024

: 21 Jun 2024 - Jonathan Hester Diagnosed

MATTEI COMPRESSORS--OEM 9635 LIBERTY ROAD, SUITE E

RANDALLSTOWN, MD US 21133

Contact: MARTY WARD jward@matteicomp.com T: (410)521-7020

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (410)521-7024