WEAR
CONTAMINATION
FLUID CONDITION


NORMAL NORMAL NORMAL


PALASYN 45


PALATEK 1701090005 - BULLET LINES


Compressor


RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		UCS06213596	UCS05848762	UCS05251760
	Sample Date		Client Info		06 Jun 2024	10 May 2023	06 May 2021
	Machine Age	hrs	Client Info		13457	11158	6982
	Oil Age	hrs	Client Info		2299	2070	2393
	Filter Age	hrs	Client Info		0	0	0
	Oil Changed		Client Info		Changed	Changed	Changed
	Filter Changed		Client Info		N/A	N/A	Not Changd
	Sample Status				NORMAL	NORMAL	NORMAL
WEAR	Iron	ppm	ASTM D5185m	>50	0	0	0
All component wear rates are normal.	Chromium	ppm	ASTM D5185m	>10	0	0	0
	Nickel	ppm	ASTM D5185m		0	0	0
	Titanium	ppm	ASTM D5185m		0	0	0
	Silver	ppm	ASTM D5185m		0	0	0
	Aluminum	ppm	ASTM D5185m	>25	0	<1	0
	Lead	ppm	ASTM D5185m	>25	0	0	0
	Copper	ppm	ASTM D5185m	>50	0	0	0
	Tin	ppm	ASTM D5185m	>15	0	0	0
	Vanadium	ppm	ASTM D5185m		0	0	0
	White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
CONTAMINATION	Silicon	ppm	ASTM D5185m	>25	2	2	<1
There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185m	>20	0	0	0
	Water		WC Method	>0.1	NEG	NEG	NEG
	Silt	scalar	*Visual	NONE	NONE	NONE	NONE
	Debris	scalar	*Visual	NONE	NONE	LIGHT	MODER
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
	Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
	Odor	scalar	*Visual	NORML	NORML	NORML	NORML
	Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
FLUID CONDITION	Sodium	ppm	ASTM D5185m		<1	0	0
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.	Boron	ppm	ASTM D5185m	0.0	0	0	0
	Barium	ppm	ASTM D5185m	0.0	0	0	0
	Molybdenum	ppm	ASTM D5185m	0	0	0	0
	Manganese	ppm	ASTM D5185m	-	0	0	0
	Magnesium	ppm	ASTM D5185m	0.0	0	0	0
	Calcium	ppm	ASTM D5185m		0	0	0
	Phosphorus	ppm	ASTM D5185m		496	554	560
	Zinc	ppm	ASTM D5185m		0	0	0
	Sulfur	ppm	ASTM D5185m		294	161	185
	Acid Number (AN)	mg KOH/g	ASTM D8045		0.05	0.11	0.118
	Visc @ 40°C	cSt	ASTM D445	39.9	43.5	41.5	40.7 CVACGRE













Certificate L2367

Laboratory Sample No.

Lab Number : 06213596

Test Package : IND 2

: UCS06213596 Unique Number : 11086460

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 18 Jun 2024 **Tested** : 20 Jun 2024

Diagnosed : 20 Jun 2024 - Wes Davis

VACUUM PUMP and COMPRESSOR 1490 GRUBER RD GREEN BAY, WI US 54313

Contact: ROBIN robin@vpc-inc.com T: (920)662-1113

F: (920)662-1116

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)