WEAR CONTAMINATION FLUID CONDITION

NORMAL NORMAL


Machine Id

US316679 FE2-TANK 2

Component New (Unused) Oil

{not provided} (--- GAL)

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History
This is a baseline read-out on the submitted sample.	Sample Number		Client Info		DC0016778		
	Sample Date		Client Info		18 Jun 2024		
	Machine Age	hrs	Client Info		0		
	Oil Age	hrs	Client Info		0		
	Filter Age	hrs	Client Info		0		
	Oil Changed		Client Info		N/A		
	Filter Changed		Client Info		N/A		
	Sample Status				NORMAL		
WEAR	Iron	ppm	ASTM D5185m		11		
	Chromium	ppm	ASTM D5185m		<1		
	Nickel	ppm	ASTM D5185m		<1		
	Titanium	ppm	ASTM D5185m		<1		
	Silver	ppm	ASTM D5185m		0		
	Aluminum	ppm	ASTM D5185m		2		
	Lead	ppm	ASTM D5185m		<1		
	Copper	ppm	ASTM D5185m		<1		
	Tin	ppm	ASTM D5185m		<1		
	Vanadium	ppm	ASTM D5185m		0		
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
CONTAMINATION	Silicon	ppm	ASTM D5185m		2		
	Potassium	ppm	ASTM D5185m	>20	- <1		
	Water	ρρ	WC Method	7 = 0	NEG		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
	Appearance	scalar	*Visual	NORML	NORML		
	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual		NEG		
FLUID CONDITION	Sodium	nnm	ASTM D5185m		0		
	Boron	ppm	ASTM D5185m		_		
	Barium	ppm	ASTM D5185m		2 <1		
	Molybdenum	ppm	ASTM D5185m		<1		
	Manganese	ppm	ASTM D5185m		<1		
	Magnesium	ppm	ASTM D5185m		2		
	Calcium	ppm	ASTM D5185m		5		
	Phosphorus	ppm	ASTM D5185m		512		
	Zinc	ppm	ASTM D5185m		7		
	Sulfur	ppm	ASTM D5185m		2094		
	Visc @ 40°C	cSt	ASTM D445		31.4		
	Visc @ 100°C	cSt	ASTM D445		5.92		
	Viscosity Index (VI)		ASTM D2270		135		





Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Lab Number : 06215220 Unique Number : 11088084

: DC0016778

Received : 19 Jun 2024 **Tested** Diagnosed

Test Package: MOB 1 (Additional Tests: FT-IR, ICP-NewOil, KV100, VI)

: 25 Jun 2024 : 25 Jun 2024 - Jonathan Hester To discuss this sample report, contact Customer Service at 1-800-237-1369.

9001 51ST PLACE COLLEGE PARK, MD US 20740

Contact: PATTI KLEITGEN patti.kleitgen@tkelevator.com T: (301)345-6400

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)