



OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL



Machine Id
JENBACHER GM02 (S/N 1144713)
Component
Biogas Engine
Fluid
MAHLER Q8 Mahler G8 SAE 40 (--- GAL)

RECOMMENDATION

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC0914303	WC0914300	WC0914297
Sample Date		Client Info		18 Jun 2024	10 Jun 2024	03 Jun 2024
Machine Age	hrs	Client Info		51402	51389	51240
Oil Age	hrs	Client Info		1604	1591	1442
Filter Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Filter Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL

WEAR

All component wear rates are normal.

Iron	ppm	ASTM D5185m	>20	8	9	8
Chromium	ppm	ASTM D5185m	>5	<1	<1	<1
Nickel	ppm	ASTM D5185m	>2	0	0	0
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m	>5	0	0	0
Aluminum	ppm	ASTM D5185m	>15	3	3	4
Lead	ppm	ASTM D5185m	>20	0	<1	0
Copper	ppm	ASTM D5185m	>15	3	4	3
Tin	ppm	ASTM D5185m	>5	5	6	5
Vanadium	ppm	ASTM D5185m		0	0	<1
White Metal	scalar	*Visual	NONE	LIGHT	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE

CONTAMINATION













There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185m	>200	71	82	80
Potassium	ppm	ASTM D5185m	>20	6	10	7
Fuel		WC Method	>4.0	<1.0	<1.0	<1.0
Water		WC Method	>.2	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
Soot %	%	*ASTM D7844	>2	0.1	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>20	8.1	8.0	8.0
Sulfation	Abs/.1mm	*ASTM D7415	>30	18.8	18.9	18.8
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.2	NEG	NEG	NEG

FLUID CONDITION

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185m	>20	15	14	18
Boron	ppm	ASTM D5185m		<1	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	1	<1
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		6	8	0
Calcium	ppm	ASTM D5185m		2363	2442	2526
Phosphorus	ppm	ASTM D5185m		398	405	432
Zinc	ppm	ASTM D5185m		465	505	492
Sulfur	ppm	ASTM D5185m		2886	2947	2964
Oxidation	Abs/.1mm	*ASTM D7414	>25	13.7	13.8	13.8
Acid Number (AN)	mg KOH/g	ASTM D8045		1.15	1.16	1.30
Base Number (BN)	mg KOH/g	ASTM D2896	8.0	5.86	5.58	5.62
Visc @ 100°C	cSt	ASTM D445	13.2	13.8	14.0	13.8



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0914303
Lab Number : 06215917
Unique Number : 11088781
Test Package : MOB 2
Received : 20 Jun 2024
Tested : 22 Jun 2024
Diagnosed : 23 Jun 2024 - Don Baldrige

PINE RIDGE
 105 BAILEY JESTER RD
 GRIFFIN, GA
 US 30224
 Contact: STEPHEN SAVAGE
 stephen.savage@cubedistrictenergy.com
 T:
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)