



# COOLANT REPORT

CORROSION	<b>NORMAL</b>
CONTAMINANTS	<b>NORMAL</b>
COOLANT CONDITION	<b>NORMAL</b>

Area

**WCLSNC**

Machine Id

**QC COOL ELC NC 09012022**

Component

**Coolant**

Fluid

**CAT EXTENDED LIFE COOLANT (ELC) (--- GAL)**

## RECOMMENDATION

No corrective action is recommended at this time. The fluid is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>WC0952332</b>	WC0952325	WC0952324
Sample Date		Client Info		<b>21 Jun 2024</b>	14 Jun 2024	13 Jun 2024
Machine Age	hrs	Client Info		<b>0</b>	0	0
Oil Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed		Client Info		<b>N/A</b>	N/A	N/A
Sample Status				<b>NORMAL</b>	NORMAL	---

## CORROSION

All metal levels are normal indicating no corrosion in the cooling system.

Iron	ppm	ASTM D6130	>2	<b>0</b>	0	---
Aluminum	ppm	ASTM D6130	>2	<b>0</b>	<1	---
Copper	ppm	ASTM D6130	>2	<b>0</b>	0	---
Lead	ppm	ASTM D6130	>2	<b>0</b>	0	---
Tin	ppm	ASTM D6130	>2	<b>0</b>	0	---
Zinc	ppm	ASTM D6130	>10	<b>0</b>	0	---

## CONTAMINANTS








There is no indication of any contamination in the coolant.

Calcium	ppm	ASTM D6130	>5	<b>0</b>	0	---
Chlorine	ppm	ASTM D6130		<b>0</b>	<1	---
Magnesium	ppm	ASTM D6130	>6	<b>0</b>	<1	---
Total Dissolved Solids				<b>276.5</b>	294.0	358.0
Coolant Appearance		*Visual	Clear	<b>normal</b>	normal	normal

## COOLANT CONDITION

Carboxylate test failed. Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

Boiling Point	°C	WC Method		<b>225</b>	225	225
Specific Gravity		*ASTM D1298		<b>1.066</b>	1.066	1.066
pH	Scale 0-14	ASTM D1287		<b>8.25</b>	8.31	8.20
Nitrites	ppm	AP-053:2009		<b>676</b>	748	824
Reserve Alkalinity	Scale 0-20	*ASTM D1121		<b>---</b>	---	---
Percentage Glycol	%	ASTM D3321		<b>48.9</b>	49.0	49.1
Freezing Point	°F	ASTM D3321		<b>-31</b>	-33	-33
Carboxylate				<b>fail</b>	fail	▲ fail
Silicon	ppm	ASTM D6130	0	<b>&lt;1</b>	1	---
Phosphorus	ppm	ASTM D6130	0	<b>0</b>	0	---
Boron	ppm	ASTM D6130	0	<b>0</b>	0	---
Molybdenum	ppm	ASTM D6130	950	<b>683</b>	698	---
Sodium	ppm	ASTM D6130		<b>3943</b>	4212	---
Potassium	ppm	ASTM D6130		<b>4</b>	3	---
Coolant Color		*Visual		<b>Red</b>	Red	Red



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0952332  
**Lab Number** : 06217243  
**Unique Number** : 11090107  
**Test Package** : COOL- ( Additional Tests: GlycolType, ICP )

**WEARCHECK LUBRICATION SERVICES QA ACCOUNT**  
 501 Madison Ave  
 Cary, NC  
 US 27513  
 Contact: WCLS CARY NC

**Received** : 21 Jun 2024  
**Tested** : 26 Jun 2024  
**Diagnosed** : 26 Jun 2024 - Jonathan Hester

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (919)379-4102  
 F: (919)379-4050