



|                 |               |
|-----------------|---------------|
| WEAR            | <b>NORMAL</b> |
| CONTAMINATION   | <b>NORMAL</b> |
| FLUID CONDITION | <b>NORMAL</b> |

Area  
**ERNA E HONEYCUTT**  
Machine Id  
**[ERNA E HONEYCUTT] 003 641346-3**  
Component  
**Starboard Main Engine**  
Fluid  
**CHEVRON DELO 710 LE (--- GAL)**

**RECOMMENDATION**

Resample at the next service interval to monitor.

| Test           | UOM | Method      | Limit/Abn | Current            | History1    | History2    |
|----------------|-----|-------------|-----------|--------------------|-------------|-------------|
| Sample Number  |     | Client Info |           | <b>MW0035232</b>   | MW0063228   | MW0063233   |
| Sample Date    |     | Client Info |           | <b>01 Jun 2024</b> | 01 May 2024 | 01 Apr 2024 |
| Machine Age    | hrs | Client Info |           | <b>10262</b>       | 9523        | 8805        |
| Oil Age        | hrs | Client Info |           | <b>10262</b>       | 9523        | 8805        |
| Filter Age     | hrs | Client Info |           | <b>0</b>           | 0           | 0           |
| Oil Changed    |     | Client Info |           | <b>N/A</b>         | Not Changd  | N/A         |
| Filter Changed |     | Client Info |           | <b>N/A</b>         | Not Changd  | N/A         |
| Sample Status  |     |             |           | <b>NORMAL</b>      | NORMAL      | NORMAL      |

**WEAR**

All component wear rates are normal.

|              |        |             |      |              |      |      |
|--------------|--------|-------------|------|--------------|------|------|
| Iron         | ppm    | ASTM D5185m | >75  | <b>26</b>    | 18   | 28   |
| Chromium     | ppm    | ASTM D5185m | >8   | <b>2</b>     | 2    | 2    |
| Nickel       | ppm    | ASTM D5185m | >2   | <b>&lt;1</b> | 0    | <1   |
| Titanium     | ppm    | ASTM D5185m | >3   | <b>&lt;1</b> | <1   | 0    |
| Silver       | ppm    | ASTM D5185m | >2   | <b>&lt;1</b> | <1   | 0    |
| Aluminum     | ppm    | ASTM D5185m | >15  | <b>3</b>     | 2    | 2    |
| Lead         | ppm    | ASTM D5185m | >18  | <b>7</b>     | 7    | 9    |
| Copper       | ppm    | ASTM D5185m | >80  | <b>17</b>    | 13   | 15   |
| Tin          | ppm    | ASTM D5185m | >14  | <b>7</b>     | 6    | 7    |
| Vanadium     | ppm    | ASTM D5185m |      | <b>&lt;1</b> | <1   | <1   |
| White Metal  | scalar | *Visual     | NONE | <b>NONE</b>  | NONE | NONE |
| Yellow Metal | scalar | *Visual     | NONE | <b>NONE</b>  | NONE | NONE |

**CONTAMINATION**

There is no indication of any contamination in the oil.


|                  |          |             |       |                |       |       |
|------------------|----------|-------------|-------|----------------|-------|-------|
| Silicon          | ppm      | ASTM D5185m | >20   | <b>5</b>       | 7     | 4     |
| Potassium        | ppm      | ASTM D5185m | >20   | <b>3</b>       | 3     | 0     |
| Fuel             |          | WC Method   | >4.0  | <b>&lt;1.0</b> | <1.0  | <1.0  |
| Water            |          | WC Method   | >0.1  | <b>NEG</b>     | NEG   | NEG   |
| Glycol           |          | WC Method   |       | <b>NEG</b>     | NEG   | NEG   |
| Soot %           | %        | *ASTM D7844 | >3    | <b>0.9</b>     | 0.5   | 0.7   |
| Nitration        | Abs/cm   | *ASTM D7624 | >20   | <b>8.8</b>     | 8.6   | 8.8   |
| Sulfation        | Abs/.1mm | *ASTM D7415 | >30   | <b>17.3</b>    | 16.7  | 17.6  |
| Silt             | scalar   | *Visual     | NONE  | <b>NONE</b>    | NONE  | NONE  |
| Debris           | scalar   | *Visual     | NONE  | <b>NONE</b>    | NONE  | NONE  |
| Sand/Dirt        | scalar   | *Visual     | NONE  | <b>NONE</b>    | NONE  | NONE  |
| Appearance       | scalar   | *Visual     | NORML | <b>NORML</b>   | NORML | NORML |
| Odor             | scalar   | *Visual     | NORML | <b>NORML</b>   | NORML | NORML |
| Emulsified Water | scalar   | *Visual     | >0.1  | <b>NEG</b>     | NEG   | NEG   |

**FLUID CONDITION**


The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

|                  |          |             |      |             |      |      |
|------------------|----------|-------------|------|-------------|------|------|
| Sodium           | ppm      | ASTM D5185m | >75  | <b>0</b>    | 2    | 0    |
| Boron            | ppm      | ASTM D5185m |      | <b>42</b>   | 43   | 42   |
| Barium           | ppm      | ASTM D5185m |      | <b>1</b>    | 0    | 0    |
| Molybdenum       | ppm      | ASTM D5185m |      | <b>47</b>   | 46   | 52   |
| Manganese        | ppm      | ASTM D5185m |      | <b>3</b>    | 1    | 2    |
| Magnesium        | ppm      | ASTM D5185m |      | <b>10</b>   | 11   | 14   |
| Calcium          | ppm      | ASTM D5185m |      | <b>3585</b> | 3439 | 4228 |
| Phosphorus       | ppm      | ASTM D5185m |      | <b>17</b>   | 10   | 6    |
| Zinc             | ppm      | ASTM D5185m | 10   | <b>7</b>    | 4    | 8    |
| Sulfur           | ppm      | ASTM D5185m |      | <b>2661</b> | 2618 | 3393 |
| Oxidation        | Abs/.1mm | *ASTM D7414 | >25  | <b>9.1</b>  | 9.5  | 9.5  |
| Base Number (BN) | mg KOH/g | ASTM D2896  | 9.2  | <b>9.57</b> | 8.97 | 9.43 |
| Visc @ 100°C     | cSt      | ASTM D445   | 15.5 | <b>15.2</b> | 14.2 | 15.1 |


**FT-IR (Direct Trend)**




**Base Number**




**Viscosity @ 100°C**




**Ferrous Alloys**




**Non-ferrous Metals**



**Viscosity @ 100°C**



**Base Number**



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513

**Sample No.** : MW0035232

**Lab Number** : 06218879

**Unique Number** : 11097076

**Test Package** : MAR 2

**Received** : 24 Jun 2024

**Tested** : 25 Jun 2024

**Diagnosed** : 25 Jun 2024 - Wes Davis

**INGRAM BARGE**

900 S 3RD ST

PADUCAH, KY

US 42003

Contact: JEFF BISHOP

jeff.bishop@ingrambarga.com

T:

F: (615)695-3697

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)