

[PMOAS3429613] GENERAC GENERATOR 13817380100 2113864 - ST LEONARD VFS AND RS Component Coolant

FLEET CHARGE (--- GAL)

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
The fluid is suitable for further service.	Sample Number		Client Info		DC0035215	DC0032094	DC0026392
	Sample Date		Client Info		12 Jun 2024	04 Dec 2023	12 May 2023
	Machine Age	hrs	Client Info		208	208	204
	Oil Age	hrs	Client Info		0	0	0
	Oil Changed		Client Info		N/A	Not Changd	Changed
	Sample Status				NORMAL	NORMAL	NORMAL
CORROSION	Total Dissolved Solids				351.0	293.5	273.5
	Coolant Appearance		*Visual	Clear	normal	normal	normal
CONTAMINANTS	Boiling Point	°C	WC Method		225		
There is no indication of any contamination in the coolant.	Specific Gravity		*ASTM D1298		1.068	1.076	1.070
	рН	Scale 0-14	ASTM D1287		9.08	9.08	9.40
	Nitrites	ppm	AP-053:2009		1652	1312	1500
	Reserve Alkalinity	Scale 0-20	*ASTM D1121				
	Percentage Glycol	%	ASTM D3321		50.5	56.5	52.3
	Freezing Point	°F	ASTM D3321		-35	-50	-40

Carboxylate

Coolant Color

*Visual

n/a


Orange


n/a

Red

n/a

Pink





KELLY GENERATOR & EQUIPMENT INC Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 : DC0035215 Received : 25 Jun 2024 1955 DALE LN Sample No. Lab Number : 06220324 OWINGS, MD Tested : 27 Jun 2024 Unique Number : 11098521 : 27 Jun 2024 - Jonathan Hester US 20736 Diagnosed Test Package : COOL- (Additional Tests: GlycolType) Contact: LESLIE SNURR Certificate L2367 LSNURR@KGE.COM To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: (410)257-5225 F: (410)257-5227 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: LESLIE SNURR - KELOWI Page 2 of 2