



COOLANT REPORT

CORROSION	NORMAL
CONTAMINANTS	NORMAL
COOLANT CONDITION	NORMAL

Area
[PMOAS3429611]
 Machine Id
2068816
 Component
Coolant
 Fluid
FLEETCHARGE (--- QTS)

RECOMMENDATION

The fluid is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		DC0037044	---	---
Sample Date		Client Info		14 Jun 2024	---	---
Machine Age	hrs	Client Info		410	---	---
Oil Age	hrs	Client Info		0	---	---
Oil Changed		Client Info		Not Changd	---	---
Sample Status				NORMAL	---	---








CORROSION

Total Dissolved Solids				239.0	---	---
Coolant Appearance		*Visual	Clear	normal	---	---

CONTAMINANTS

There is no indication of any contamination in the coolant.

Boiling Point	°C	WC Method		228	---	---
Specific Gravity		*ASTM D1298		1.076	---	---
pH	Scale 0-14	ASTM D1287		8.57	---	---
Nitrites	ppm	AP-053:2009		1352	---	---
Reserve Alkalinity	Scale 0-20	*ASTM D1121		---	---	---
Percentage Glycol	%	ASTM D3321		56.6	---	---
Freezing Point	°F	ASTM D3321		-50	---	---
Carboxylate				n/a	---	---
Coolant Color		*Visual		Red	---	---



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : DC0037044 **Received** : 25 Jun 2024
Lab Number : 06220327 **Tested** : 27 Jun 2024
Unique Number : 11098524 **Diagnosed** : 27 Jun 2024 - Jonathan Hester
Test Package : COOL- (Additional Tests: GlycolType)

KELLY GENERATOR & EQUIPMENT INC
 1955 DALE LN
 OWINGS, MD
 US 20736
 Contact: LESLIE SNURR
 LSNURR@KGE.COM
 T: (410)257-5225
 F: (410)257-5227

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)