**WEAR** CONTAMINATION **FLUID CONDITION** 

**NORMAL NORMAL NORMAL** 

Machine Id

WC0827477

Component Diesel Engine

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
	Sample Number		Client Info		WC0827477		
Resample at the next service interval to monitor. Please specify the component make and model with your next sample.	Sample Date		Client Info		25 Jun 2024		
	Machine Age	hrs	Client Info		0		
	Oil Age	hrs	Client Info		0		
	Filter Age	hrs	Client Info		0		
	Oil Changed		Client Info		Changed		
	Filter Changed		Client Info		Changed		
	Sample Status				NORMAL		
WEAR	Iron	ppm	ASTM D5185m	>100	<1		
All component wear rates are normal.	Chromium	ppm	ASTM D5185m	>20	0		
	Nickel	ppm	ASTM D5185m		0		
	Titanium	ppm	ASTM D5185m		0		
	Silver	ppm	ASTM D5185m	>3	0		
	Aluminum	ppm	ASTM D5185m		2		
	Lead	ppm	ASTM D5185m		0		
	Copper	ppm	ASTM D5185m		3		
	Tin	ppm	ASTM D5185m		0		
	Vanadium	ppm	ASTM D5185m		0		
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
CONTAMINATION	Silicon	nnm	ASTM D5185m	> 25	7		
CONTAMINATION	Potassium	ppm	ASTM D5185m		4		
There is no indication of any contamination in the oil.	Fuel	ppm	WC Method		<1.0		
	Water		WC Method		NEG		
	Glycol		WC Method	>0.2	NEG		
	Soot %	%	*ASTM D7844	. 2	0		
	Nitration	Abs/cm	*ASTM D7624	>20	4.0		
	Sulfation	Abs/.1mm	*ASTM D7024		18.5		
	Silt	scalar	*Visual	NONE	NONE		
	Debris		*Visual	NONE	NONE		
	Sand/Dirt	scalar scalar	*Visual	NONE	NONE		
			*Visual	NORML	NORML		
	Appearance Odor	scalar scalar	*Visual	NORML	NORML		
	Emulsified Water		*Visual	>0.2	NEG		
			Visuai				
FLUID CONDITION	Sodium	ppm	ASTM D5185m		1		
The BN result indicates that there is suitable alkalinity remaining in the	Boron	ppm	ASTM D5185m		398		
oil. The condition of the oil is suitable for further service.	Barium	ppm	ASTM D5185m		0		
	Molybdenum	ppm	ASTM D5185m	100	81		
	Manganese	ppm	ASTM D5185m		<1		
	Magnesium	ppm	ASTM D5185m		420		
	Calcium	ppm		3000	1395		
	Phosphorus	ppm	ASTM D5185m		994		
	Zinc	ppm	ASTM D5185m		1241		
		ppm	ASTM D5185m	4250	3822		
	Sulfur	PP					
	Oxidation	Abs/.1mm	*ASTM D7414		12.4		
		Abs/.1mm			12.4 8.2		





Certificate L2367

Laboratory Sample No.

: WC0827477 Lab Number : 06220577

Unique Number : 11098774 Test Package : MOB 1 ( Additional Tests: TBN )

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 25 Jun 2024 **Tested** 

Diagnosed

: 27 Jun 2024 : 27 Jun 2024 - Wes Davis

400 PENNSBURY MEMORIAL RD MORRISVILLE, PA

US 19067

**PENNSBURY MANOR** 

Contact: JOSEPH CAMELI

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: