



OIL ANALYSIS REPORT

| | |
|-----------------|--------|
| WEAR | NORMAL |
| CONTAMINATION | NORMAL |
| FLUID CONDITION | NORMAL |



Machine Id
ENG 4A
Component
Left Biogas Engine
Fluid
D-A Lubricant Blue Flame HB-5 40W (110 GAL)

RECOMMENDATION

Resample at the next service interval to monitor.

| Test | UOM | Method | Limit/Abn | Current | History1 | History2 |
|----------------|-----|-------------|-----------|--------------------|-------------|-------------|
| Sample Number | | Client Info | | WC0935623 | WC0935622 | WC0935612 |
| Sample Date | | Client Info | | 24 Jun 2024 | 17 Jun 2024 | 06 May 2024 |
| Machine Age | hrs | Client Info | | 115800 | 115634 | 114636 |
| Oil Age | hrs | Client Info | | 427 | 261 | 1104 |
| Filter Age | hrs | Client Info | | 427 | 261 | 1104 |
| Oil Changed | | Client Info | | N/A | N/A | N/A |
| Filter Changed | | Client Info | | N/A | N/A | N/A |
| Sample Status | | | | NORMAL | NORMAL | ABNORMAL |

WEAR

All component wear rates are normal.

| | | | | | | |
|--------------|--------|-------------|------|--------------|------|------|
| Iron | ppm | ASTM D5185m | >45 | 5 | 1 | 3 |
| Chromium | ppm | ASTM D5185m | >2 | <1 | 0 | <1 |
| Nickel | ppm | ASTM D5185m | >2 | <1 | 0 | <1 |
| Titanium | ppm | ASTM D5185m | | <1 | 0 | <1 |
| Silver | ppm | ASTM D5185m | >5 | <1 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m | >10 | 2 | 2 | 2 |
| Lead | ppm | ASTM D5185m | >5 | 2 | <1 | 3 |
| Copper | ppm | ASTM D5185m | >14 | 1 | <1 | 1 |
| Tin | ppm | ASTM D5185m | >13 | 3 | 2 | 4 |
| Vanadium | ppm | ASTM D5185m | | <1 | 0 | <1 |
| White Metal | scalar | *Visual | NONE | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE | NONE |

CONTAMINATION













There is no indication of any contamination in the oil.

| | | | | | | |
|------------------|----------|-------------|-------|----------------|-------|-------|
| Silicon | ppm | ASTM D5185m | >200 | 124 | 81 | ▲ 204 |
| Potassium | ppm | ASTM D5185m | >20 | <1 | 2 | 2 |
| Fuel | | WC Method | >4.0 | <1.0 | <1.0 | <1.0 |
| Water | | WC Method | >0.1 | NEG | NEG | NEG |
| Glycol | | WC Method | | NEG | NEG | NEG |
| Soot % | % | *ASTM D7844 | | 0 | 0 | 0 |
| Nitration | Abs/cm | *ASTM D7624 | >20 | 5.3 | 5.0 | 5.9 |
| Sulfation | Abs/.1mm | *ASTM D7415 | >30 | 17.7 | 16.5 | 19.8 |
| Silt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.1 | NEG | NEG | NEG |

FLUID CONDITION

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| | | | | | | |
|------------------|----------|-------------|-----|--------------|------|------|
| Sodium | ppm | ASTM D5185m | | 0 | 2 | 0 |
| Boron | ppm | ASTM D5185m | | 2 | 1 | 1 |
| Barium | ppm | ASTM D5185m | | 1 | 0 | 1 |
| Molybdenum | ppm | ASTM D5185m | | 2 | 0 | 6 |
| Manganese | ppm | ASTM D5185m | | <1 | <1 | 0 |
| Magnesium | ppm | ASTM D5185m | | 11 | 12 | 23 |
| Calcium | ppm | ASTM D5185m | | 1442 | 1448 | 1728 |
| Phosphorus | ppm | ASTM D5185m | | 319 | 357 | 480 |
| Zinc | ppm | ASTM D5185m | | 432 | 444 | 548 |
| Sulfur | ppm | ASTM D5185m | | 2691 | 3265 | 3886 |
| Oxidation | Abs/.1mm | *ASTM D7414 | >25 | 11.6 | 10.4 | 14.4 |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | | 1.09 | 0.59 | 1.49 |
| Base Number (BN) | mg KOH/g | ASTM D2896 | | 3.93 | 4.03 | 3.52 |
| Visc @ 100°C | cSt | ASTM D445 | | 13.0 | 13.2 | 13.5 |



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0935623
Lab Number : 06221849
Unique Number : 11100046
Test Package : MOB 2

Received : 26 Jun 2024
Tested : 29 Jun 2024
Diagnosed : 29 Jun 2024 - Don Baldrige

BROOME ENERGY
 286 KNAPP ROAD
 BINGHAMTON, NY
 US 13905

Contact: RUSS MERCER
 BroomeEnergy@gmail.com
 T: (607)766-0358
 F: (607)766-0357

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)