



WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Area

DANIEL P MECKLENBORG

Machine Id

[DANIEL P MECKLENBORG] 007 608409-7

Component

Port Genset

Fluid

CHEVRON DELO 400 XLE 15W40 (7 GAL)

RECOMMENDATION

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		MW06221933	MW06176432	MW06017687
Sample Date		Client Info		28 May 2024	25 Apr 2024	06 Nov 2023
Machine Age	hrs	Client Info		36268	35884	34690
Oil Age	hrs	Client Info		384	436	400
Filter Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Filter Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL

WEAR

All component wear rates are normal.

Iron	ppm	ASTM D5185m	>50	7	6	5
Chromium	ppm	ASTM D5185m	>4	<1	<1	0
Nickel	ppm	ASTM D5185m	>2	0	<1	<1
Titanium	ppm	ASTM D5185m		<1	<1	<1
Silver	ppm	ASTM D5185m	>5	0	0	0
Aluminum	ppm	ASTM D5185m	>12	2	3	4
Lead	ppm	ASTM D5185m	>17	<1	<1	<1
Copper	ppm	ASTM D5185m	>70	<1	2	0
Tin	ppm	ASTM D5185m	>15	0	<1	<1
Vanadium	ppm	ASTM D5185m		0	<1	<1
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE

CONTAMINATION








There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185m	>25	5	6	6
Potassium	ppm	ASTM D5185m	>20	1	2	1
Fuel		WC Method	>4.0	<1.0	<1.0	<1.0
Water		WC Method	>0.1	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
Soot %	%	*ASTM D7844		0.3	0.2	0.3
Nitration	Abs/cm	*ASTM D7624	>20	7.1	7.1	7.0
Sulfation	Abs/.1mm	*ASTM D7415	>30	22.4	23.5	23.5
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG

FLUID CONDITION

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185m		2	0	2
Boron	ppm	ASTM D5185m		314	391	293
Barium	ppm	ASTM D5185m		0	2	0
Molybdenum	ppm	ASTM D5185m		103	138	116
Manganese	ppm	ASTM D5185m		3	2	1
Magnesium	ppm	ASTM D5185m		520	647	634
Calcium	ppm	ASTM D5185m		1657	1577	1507
Phosphorus	ppm	ASTM D5185m	760	955	755	737
Zinc	ppm	ASTM D5185m	830	1081	857	819
Sulfur	ppm	ASTM D5185m	2770	3437	2767	2515
Oxidation	Abs/.1mm	*ASTM D7414	>25	16.1	17.1	16.9
Base Number (BN)	mg KOH/g	ASTM D2896	10.7	8.0	8.6	8.5
Visc @ 100°C	cSt	ASTM D445	14.9	13.6	13.5	13.4



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : MW06221933
Lab Number : 06221933
Unique Number : 11100130
Test Package : MAR 2
Received : 26 Jun 2024
Tested : 28 Jun 2024
Diagnosed : 28 Jun 2024 - Wes Davis

INGRAM BARGE
 900 S 3RD ST
 PADUCAH, KY
 US 42003

Contact: DALE MORIE
 dale.morie@ingrambarga.com
 T: (270)415-4467
 F: (615)695-3697

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)