



# COOLANT REPORT

CORROSION	<b>NORMAL</b>
CONTAMINANTS	<b>NORMAL</b>
COOLANT CONDITION	<b>NORMAL</b>

Area  
**BOWERMAN - ORANGE COUNTY CA**

Machine Id  
**SUTTON STROMART BOW 7**

Component  
**Coolant**

Fluid  
**CHEVRON DELO EXTENDED LIFE COOLANT (--- GAL)**

## RECOMMENDATION

No corrective action is recommended at this time. The fluid is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>WC0848226</b>	WC0848293	WC0848289
Sample Date		Client Info		<b>25 Jun 2024</b>	29 Mar 2024	09 Jan 2024
Machine Age	hrs	Client Info		<b>66129</b>	0	0
Oil Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed		Client Info		<b>N/A</b>	N/A	N/A
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL










## CORROSION

Total Dissolved Solids				<b>430.5</b>	411.0	463.5
Coolant Appearance		*Visual	Clear	<b>normal</b>	normal	normal

## CONTAMINANTS

There is no indication of any contamination in the coolant.

Boiling Point	°C	WC Method		<b>232</b>	232	---
Specific Gravity		*ASTM D1298		<b>1.083</b>	1.083	1.084
pH	Scale 0-14	ASTM D1287		<b>8.01</b>	8.18	7.99
Nitrites	ppm	AP-053:2009		<b>NT</b>	NT	NT
Reserve Alkalinity	Scale 0-20	*ASTM D1121		<b>---</b>	---	---
Percentage Glycol	%	ASTM D3321		<b>63.7</b>	63.6	64.2
Freezing Point	°F	ASTM D3321		<b>-62</b>	-62	-63
Carboxylate				<b>fail</b>	fail	pass
Coolant Color		*Visual		<b>Red</b>	Orange	Red



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0848226 **Received** : 27 Jun 2024  
**Lab Number** : 06223075 **Tested** : 01 Jul 2024  
**Unique Number** : 11101272 **Diagnosed** : 01 Jul 2024 - Jonathan Hester  
**Test Package** : COOL- ( Additional Tests: GlycolType, TAN Man, TBN )

**MONTAUK ENERGY CAPITAL LLC (TEXAS) LP**  
 1412 N SAM HOUSTON PKWY E, SUITE 100  
 HOUSTON, TX  
 US 77032  
 Contact: DAMON MCCLENAN  
 dmcclenan@montaukenergy.com  
 T: (713)781-1126  
 F: (713)781-1127

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)