
**WEAR** CONTAMINATION **FLUID CONDITION** 

**NORMAL ATTENTION** NORMAL

## **ROTO XTEND [421783]** ATLAS COPCO API875421 - WYTECH Component Compressor

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
No corrective action is recommended at this time. Resample at the next service interval to monitor.	Sample Number		Client Info		UCH06227619		
	Sample Date		Client Info		11 Jun 2024		
	Machine Age	hrs	Client Info		5156		
	Oil Age	hrs	Client Info		5156		
	Filter Age	hrs	Client Info		0		
	Oil Changed		Client Info		N/A		
	Filter Changed		Client Info		N/A		
	Sample Status				ATTENTION		
WEAR	Iron	ppm	ASTM D5185m	>50	0		
All component wear rates are normal.	Chromium	ppm	ASTM D5185m	>5	<1		
	Nickel	ppm	ASTM D5185m		1		
	Titanium	ppm	ASTM D5185m		0		
	Silver	ppm	ASTM D5185m		0		
	Aluminum	ppm	ASTM D5185m	>15	2		
	Lead	ppm	ASTM D5185m	>65	0		
	Copper	ppm	ASTM D5185m	>65	0		
	Tin	ppm	ASTM D5185m	>10	0		
	Vanadium	ppm	ASTM D5185m		0		
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
CONTAMINATION	Silicon	nnm	ASTM D5185m	. 25	<b>42</b>		
Elemental level of silicon (Si) above normal.	Potassium	ppm	ASTM D5185m		<1		
	Water	%	ASTM D5103111		NEG		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
	Appearance	scalar	*Visual	NORML	NORML		
	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water		*Visual	>0.1	NEG		
ELLID CONDITION	· · · · · · · · · · · · · · · · · · ·		AOTAB				
FLUID CONDITION	Sodium	ppm	ASTM D5185m		0		
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.	Boron	ppm	ASTM D5185m		0		
	Barium	ppm	ASTM D5185m		0		
	Molybdenum	ppm	ASTM D5185m		0		
	Manganese	ppm	ASTM D5185m		0		
	Magnesium	ppm	ASTM D5185m		<1		
	Calcium	ppm	ASTM D5185m		0		
	Phosphorus	ppm	ASTM D5185m		16		
	Zinc	ppm	ASTM D5185m		12		
	Sulfur	ppm	ASTM D5185m	0.14	51		
	Acid Number (AN)	mg KOH/g	ASTM D8045		0.169		
Report Id: UCAIRCAR IWUSCARI 06227619 (Generated: 07/08/2024 15:03:17) Rev: 1	Visc @ 40°C	cSt	ASTM D445		46.3 Location: EL		







Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Lab Number : 06227619 Unique Number : 11111112

: UCH06227619

Received : 03 Jul 2024 **Tested** : 08 Jul 2024 : 08 Jul 2024 - Jonathan Hester Diagnosed

**AIRMATIC COMPRESSOR SYSTEMS** 700 WASHINGTON AVE

CARLSTADT, NJ US 07072 Contact: ELVIN DIAZ

Test Package : IND 2 ( Additional Tests: KF ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

ediaz@airmaticcompressor.com;canastasio@wearcheckusa.com T: (800)864-7621

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (201)342-6241