

PALLUBE 32 SULLIVAN PALATEK 1601070009 - RCL COMPONENTS Component Compressor

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		UCS06230214	UCS06111547	
'	Sample Date		Client Info		01 Jul 2024	01 Mar 2024	
	Machine Age	hrs	Client Info		18273	17780	
	Oil Age	hrs	Client Info		0	3747	
	Filter Age	hrs	Client Info		0	1941	
	Oil Changed		Client Info		Changed	Not Changd	
	Filter Changed		Client Info		Changed	Changed	
	Sample Status				NORMAL	NORMAL	
WEAR	Iron	ppm	ASTM D5185m	>50	<1	<1	
All component wear rates are normal.	Chromium	ppm	ASTM D5185m	>10	0	<1	
	Nickel	ppm	ASTM D5185m		0	0	
	Titanium	ppm	ASTM D5185m		0	<1	
	Silver	ppm	ASTM D5185m		0	0	
	Aluminum	ppm	ASTM D5185m	>25	0	2	
	Lead	ppm	ASTM D5185m	>25	0	0	
	Copper	ppm	ASTM D5185m	>50	0	<1	
	Tin	ppm	ASTM D5185m	>15	0	<1	
	Vanadium	ppm	ASTM D5185m		0	0	
	White Metal	scalar	*Visual	NONE	NONE	NONE	
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
CONTAMINATION	Silicon	ppm	ASTM D5185m	>25	2	<1	
There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185m	>20	2	4	
	Water		WC Method	>0.1	NEG	NEG	
	Silt	scalar	*Visual	NONE	NONE	NONE	
	Debris	scalar	*Visual	NONE	NONE	NONE	
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
	Appearance	scalar	*Visual	NORML	NORML	NORML	
	Odor	scalar	*Visual	NORML	NORML	NORML	
	Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	
FLUID CONDITION	Sodium	ppm	ASTM D5185m		19	62	
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.	Boron	ppm	ASTM D5185m	1	0	0	
	Barium	ppm	ASTM D5185m	730	512	240	
	Molybdenum	ppm	ASTM D5185m	0	<1	0	
	Manganese	ppm	ASTM D5185m	0.0	0	0	
	Magnesium	ppm	ASTM D5185m	0	23	<1	
	Calcium	ppm	ASTM D5185m	0	21	5	
	Phosphorus	ppm	ASTM D5185m	0	25	2	
	Zinc	ppm	ASTM D5185m	0	28	2	
	Sulfur	ppm	ASTM D5185m	590	811	435	
	Acid Number (AN)	mg KOH/g	ASTM D8045	0.14	0.084	0.26	

Visc @ 40°C


cSt

Contact/Location: JAY GIANNINI - UCBLAMEM

44.1

42.2

ASTM D445 42.8



Sample No. : UCS06230214 Received : 08 Jul 2024 Lab Number : 06230214 Tested : 09 Jul 2024 MEMPHIS, TN Unique Number : 11113707 Diagnosed : 10 Jul 2024 - Jonathan Hester US 38133 Test Package : IND 2 Contact: JAY GIANNINI Certificate L2367 JGIANNINI@BLAKEANDPENDLETON.COM To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F:

Ø