



OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Area
ULTRACHEM DPO [9721]
Machine Id
KAESER 1054 - CSDX.4C - FISHER CONTROLS
Component
Compressor
Fluid
ULTRACHEM CHEMLUBE PLUS 10 (9 GAL)

RECOMMENDATION

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC0924302	WC0924348	WC06094348
Sample Date		Client Info		03 Jul 2024	01 Jul 2024	19 Feb 2024
Machine Age	hrs	Client Info		19100	11092	0
Oil Age	hrs	Client Info		1344	2047	754
Filter Age	hrs	Client Info		690	2047	754
Oil Changed		Client Info		Changed	Changed	Not Changd
Filter Changed		Client Info		Changed	Changed	Not Changd
Sample Status				NORMAL	---	NORMAL

WEAR

All component wear rates are normal.

Iron	ppm	ASTM D5185m	>50	1	---	1
Chromium	ppm	ASTM D5185m	>10	<1	---	<1
Nickel	ppm	ASTM D5185m	>3	<1	---	0
Titanium	ppm	ASTM D5185m	>3	<1	---	0
Silver	ppm	ASTM D5185m	>2	<1	---	0
Aluminum	ppm	ASTM D5185m	>10	2	---	1
Lead	ppm	ASTM D5185m	>10	<1	---	0
Copper	ppm	ASTM D5185m	>50	4	---	4
Tin	ppm	ASTM D5185m	>10	<1	---	<1
Vanadium	ppm	ASTM D5185m		<1	---	0
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE

CONTAMINATION







There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185m	>25	1	---	<1
Potassium	ppm	ASTM D5185m	>20	1	---	<1
Water		WC Method	>0.05	NEG	NEG	NEG
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG

FLUID CONDITION

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185m		0	---	0
Boron	ppm	ASTM D5185m	0.1	0	---	0
Barium	ppm	ASTM D5185m	0.8	11	---	3
Molybdenum	ppm	ASTM D5185m	0	<1	---	0
Manganese	ppm	ASTM D5185m	0.9	<1	---	0
Magnesium	ppm	ASTM D5185m	0	0	---	<1
Calcium	ppm	ASTM D5185m	0	0	---	0
Phosphorus	ppm	ASTM D5185m	409	205	---	264
Zinc	ppm	ASTM D5185m	0	32	---	54
Sulfur	ppm	ASTM D5185m	1290	890	---	998
Acid Number (AN)	mg KOH/g	ASTM D8045	0.537	0.21	▲ 1.51	0.28
Visc @ 40°C	cSt	ASTM D445	44.56	42.9	49.2	43.3



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0924302
Lab Number : 06231565
Unique Number : 11115058
Test Package : IND 2
Received : 09 Jul 2024
Tested : 10 Jul 2024
Diagnosed : 10 Jul 2024 - Wes Davis

DELTA INDUSTRIES - CEDAR RAPIDS
 6540 4TH ST SW UNIT A
 CEDAR RAPIDS, IA
 US 52404
 Contact: MICHAEL FERRIS
 wearcheck@deltaind.net
 T: (319)862-2500
 F: (319)862-2501

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)