



# OIL ANALYSIS REPORT

|                 |        |
|-----------------|--------|
| WEAR            | NORMAL |
| CONTAMINATION   | NORMAL |
| FLUID CONDITION | NORMAL |

Machine Id  
**OSHKOSH 4430**  
 Component  
**Diesel Engine**  
 Fluid  
**DIESEL ENGINE OIL SAE 15W40 (--- GAL)**

## RECOMMENDATION

Resample at the next service interval to monitor.

| Test           | UOM | Method      | Limit/Abn | Current            | History1    | History2    |
|----------------|-----|-------------|-----------|--------------------|-------------|-------------|
| Sample Number  |     | Client Info |           | <b>WC0949242</b>   | WC0917151   | WC0893811   |
| Sample Date    |     | Client Info |           | <b>12 Jun 2024</b> | 17 May 2024 | 01 Feb 2024 |
| Machine Age    | mls | Client Info |           | <b>13171</b>       | 12498       | 9955        |
| Oil Age        | mls | Client Info |           | <b>0</b>           | 0           | 0           |
| Filter Age     | mls | Client Info |           | <b>0</b>           | 0           | 0           |
| Oil Changed    |     | Client Info |           | <b>Changed</b>     | Changed     | Changed     |
| Filter Changed |     | Client Info |           | <b>Changed</b>     | Changed     | Changed     |
| Sample Status  |     |             |           | <b>NORMAL</b>      | NORMAL      | NORMAL      |

## WEAR

Metal levels are typical for a new component breaking in.

|              |        |             |      |              |      |      |
|--------------|--------|-------------|------|--------------|------|------|
| Iron         | ppm    | ASTM D5185m | >100 | <b>4</b>     | 6    | 6    |
| Chromium     | ppm    | ASTM D5185m | >20  | <b>&lt;1</b> | <1   | <1   |
| Nickel       | ppm    | ASTM D5185m | >4   | <b>0</b>     | 0    | 0    |
| Titanium     | ppm    | ASTM D5185m |      | <b>&lt;1</b> | 0    | 0    |
| Silver       | ppm    | ASTM D5185m | >3   | <b>&lt;1</b> | 0    | 0    |
| Aluminum     | ppm    | ASTM D5185m | >20  | <b>2</b>     | 2    | <1   |
| Lead         | ppm    | ASTM D5185m | >40  | <b>&lt;1</b> | 0    | 0    |
| Copper       | ppm    | ASTM D5185m | >330 | <b>&lt;1</b> | <1   | 0    |
| Tin          | ppm    | ASTM D5185m | >15  | <b>&lt;1</b> | 0    | 0    |
| Vanadium     | ppm    | ASTM D5185m |      | <b>&lt;1</b> | 0    | 0    |
| White Metal  | scalar | *Visual     | NONE | <b>NONE</b>  | NONE | NONE |
| Yellow Metal | scalar | *Visual     | NONE | <b>NONE</b>  | NONE | NONE |

## CONTAMINATION












There is no indication of any contamination in the oil.

|                  |          |             |       |                |       |       |
|------------------|----------|-------------|-------|----------------|-------|-------|
| Silicon          | ppm      | ASTM D5185m | >25   | <b>3</b>       | 3     | 2     |
| Potassium        | ppm      | ASTM D5185m | >20   | <b>2</b>       | 2     | 0     |
| Fuel             |          | WC Method   | >5    | <b>&lt;1.0</b> | <1.0  | <1.0  |
| Water            |          | WC Method   | >0.2  | <b>NEG</b>     | NEG   | NEG   |
| Glycol           |          | WC Method   |       | <b>NEG</b>     | NEG   | NEG   |
| Soot %           | %        | *ASTM D7844 | >3    | <b>0.1</b>     | 0.2   | 0.3   |
| Nitration        | Abs/cm   | *ASTM D7624 | >20   | <b>4.9</b>     | 5.8   | 6.0   |
| Sulfation        | Abs/.1mm | *ASTM D7415 | >30   | <b>17.3</b>    | 17.6  | 18.0  |
| Silt             | scalar   | *Visual     | NONE  | <b>NONE</b>    | NONE  | NONE  |
| Debris           | scalar   | *Visual     | NONE  | <b>NONE</b>    | NONE  | NONE  |
| Sand/Dirt        | scalar   | *Visual     | NONE  | <b>NONE</b>    | NONE  | NONE  |
| Appearance       | scalar   | *Visual     | NORML | <b>NORML</b>   | NORML | NORML |
| Odor             | scalar   | *Visual     | NORML | <b>NORML</b>   | NORML | NORML |
| Emulsified Water | scalar   | *Visual     | >0.2  | <b>NEG</b>     | NEG   | NEG   |

## FLUID CONDITION

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

|                  |          |             |      |             |      |      |
|------------------|----------|-------------|------|-------------|------|------|
| Sodium           | ppm      | ASTM D5185m | >158 | <b>0</b>    | <1   | <1   |
| Boron            | ppm      | ASTM D5185m | 250  | <b>6</b>    | 9    | 2    |
| Barium           | ppm      | ASTM D5185m | 10   | <b>0</b>    | 0    | 0    |
| Molybdenum       | ppm      | ASTM D5185m | 100  | <b>57</b>   | 59   | 57   |
| Manganese        | ppm      | ASTM D5185m |      | <b>0</b>    | 0    | <1   |
| Magnesium        | ppm      | ASTM D5185m | 450  | <b>890</b>  | 883  | 935  |
| Calcium          | ppm      | ASTM D5185m | 3000 | <b>1084</b> | 1058 | 1031 |
| Phosphorus       | ppm      | ASTM D5185m | 1150 | <b>1050</b> | 1083 | 1065 |
| Zinc             | ppm      | ASTM D5185m | 1350 | <b>1192</b> | 1227 | 1241 |
| Sulfur           | ppm      | ASTM D5185m | 4250 | <b>2954</b> | 3103 | 3031 |
| Oxidation        | Abs/.1mm | *ASTM D7414 | >25  | <b>12.9</b> | 13.3 | 13.5 |
| Base Number (BN) | mg KOH/g | ASTM D2896  | 8.5  | <b>9.3</b>  | 9.4  | 9.0  |
| Visc @ 100°C     | cSt      | ASTM D445   | 14.4 | <b>13.9</b> | 13.9 | 14.2 |



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0949242  
**Lab Number** : 06233014  
**Unique Number** : 11116507  
**Test Package** : MOB 1 ( Additional Tests: TBN )

**Received** : 11 Jul 2024  
**Tested** : 11 Jul 2024  
**Diagnosed** : 11 Jul 2024 - Wes Davis

**CONCRETE SERVICE CO - FAY BLOCK**  
 161 BUILDERS BLVD  
 FAYETTEVILLE, NC  
 US 28301

Contact: BRYAN VANNIMAN  
 bryanvanniman@fayblock.com

T: (800)326-9198

F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)