



OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Machine Id
COGEN 1-1 DAY TANK
Component
Natural Gas Engine
Fluid
MOBIL PEGASUS 805 (--- GAL)

RECOMMENDATION

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		JIC0001231	JIC0001230	JIC0001223
Sample Date		Client Info		28 Jun 2024	28 Jun 2024	01 Jun 2024
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Filter Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Filter Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL

WEAR

All component wear rates are normal.

Iron	ppm	ASTM D5185m	>50	1	<1	<1
Chromium	ppm	ASTM D5185m	>4	<1	<1	<1
Nickel	ppm	ASTM D5185m	>2	0	0	0
Titanium	ppm	ASTM D5185m		<1	<1	<1
Silver	ppm	ASTM D5185m	>3	<1	<1	0
Aluminum	ppm	ASTM D5185m	>9	2	2	2
Lead	ppm	ASTM D5185m	>30	<1	0	0
Copper	ppm	ASTM D5185m	>35	<1	<1	<1
Tin	ppm	ASTM D5185m	>4	<1	<1	0
Vanadium	ppm	ASTM D5185m		<1	<1	0
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE

CONTAMINATION

There is no indication of any contamination in the oil.


Silicon	ppm	ASTM D5185m	>+100	4	4	5
Potassium	ppm	ASTM D5185m	>20	2	1	1
Water		WC Method	>0.1	NEG	NEG	NEG
Soot %	%	*ASTM D7844		0	0	0
Nitration	Abs/cm	*ASTM D7624	>20	4.4	2.8	4.3
Sulfation	Abs/.1mm	*ASTM D7415	>30	15.7	14.1	15.6
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG

FLUID CONDITION


The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185m		0	0	0
Boron	ppm	ASTM D5185m	80	0	<1	0
Barium	ppm	ASTM D5185m		0	0	<1
Molybdenum	ppm	ASTM D5185m		<1	2	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m		4	5	4
Calcium	ppm	ASTM D5185m	1020	1385	1436	1385
Phosphorus	ppm	ASTM D5185m	220	290	274	317
Zinc	ppm	ASTM D5185m	230	338	345	340
Sulfur	ppm	ASTM D5185m	1000	2079	2817	2092
Oxidation	Abs/.1mm	*ASTM D7414	>25	10.7	8.7	10.6
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.246	0.573	0.792
Base Number (BN)	mg KOH/g	ASTM D2896	6.4	6.19	4.50	5.96
Visc @ 100°C	cSt	ASTM D445	13.5	13.3	13.2	13.4


FT-IR (Direct Trend)




Iron (ppm)




Lead (ppm)




Acid Number




Aluminum (ppm)




Chromium (ppm)




Base Number




Copper (ppm)




Silicon (ppm)




Viscosity @ 100°C



Viscosity @ 100°C



Base Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : JIC0001231

Lab Number : 06234020

Unique Number : 11122854

Test Package : MOB 2

Received : 11 Jul 2024

Tested : 17 Jul 2024

Diagnosed : 17 Jul 2024 - Jonathan Hester

ABBVIE LTD UTILITES DIVISION

ROAD NO 2 KM M59.2

BARCELONETA, PR

PR 00617

Contact: NOEL VALENTIN

noel.valentin@abbvie.com

T:

F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)