

WEAR CONTAMINATION FLUID CONDITION

NORMAL NORMAL NORMAL




[20242913]

## Carerpillar 14665 Rothgeb Gen 2 275kw

Radiator Coolant

Fluid {not pro	vided} (20 GAL)							
RECOMMENDATION		Test	UOM	Method	Limit/Abn	Current	History1	History2
The fluid is suitable for further service.		Sample Number		Client Info		DC0037072		
		Sample Date		Client Info		24 Jun 2024		
		Machine Age	hrs	Client Info		0		
		Oil Age	hrs	Client Info		0		
		Filter Age	hrs	Client Info		0		
		Oil Changed		Client Info		Not Changd		
		Filter Changed		Client Info		N/A		
		Sample Status				NORMAL		
WEAR		Total Dissolved Solids				218.0		
		Coolant Appearance		*Visual	Clear	normal		
CONTAMINATION		Coolant Appearance Water		*Visual WC Method	Clear	normal NEG		
	nation in the coolant.		°C		Clear			
FLUID CONDITION  Glycol and nitrite levels are acceptab		Water	°C	WC Method	Clear	NEG		
FLUID CONDITION		Water Boiling Point	°C Scale 0-14	WC Method WC Method	Clear	NEG 222		
FLUID CONDITION  Glycol and nitrite levels are acceptab		Water  Boiling Point  Specific Gravity		WC Method WC Method *ASTM D1298	Clear	NEG 222 1.056		
FLUID CONDITION  Glycol and nitrite levels are acceptab		Water  Boiling Point  Specific Gravity pH	Scale 0-14	WC Method WC Method *ASTM D1298 ASTM D1287	Clear	NEG 222 1.056 9.07		
FLUID CONDITION  Glycol and nitrite levels are acceptab		Water  Boiling Point Specific Gravity pH Nitrites Reserve Alkalinity Percentage Glycol	Scale 0-14 ppm Scale 0-20	WC Method WC Method *ASTM D1298 ASTM D1287 AP-053:2009	Clear	NEG 222 1.056 9.07 788		
FLUID CONDITION  Glycol and nitrite levels are acceptab		Water  Boiling Point Specific Gravity pH Nitrites Reserve Alkalinity	Scale 0-14 ppm Scale 0-20	WC Method  *ASTM D1298  ASTM D1287  AP-053:2009  *ASTM D1121	Clear	NEG 222 1.056 9.07 788		   
FLUID CONDITION  Glycol and nitrite levels are acceptab		Water  Boiling Point Specific Gravity pH Nitrites Reserve Alkalinity Percentage Glycol	Scale 0-14 ppm Scale 0-20 %	WC Method  *ASTM D1298  ASTM D1287  AP-053:2009  *ASTM D1121  ASTM D3321	Clear	NEG 222 1.056 9.07 788 41.1		





Certificate L2367

Laboratory Sample No.

Lab Number : 06234390 Unique Number : 11123224

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : DC0037072 Received **Tested** 

Diagnosed Test Package : COOL- ( Additional Tests: BoilingPoint, COOL, GlycolType, ICP, KV40, SCREEN ) Contact: E. NOEL

: 16 Jul 2024 : 16 Jul 2024 - Jonathan Hester

: 11 Jul 2024

**JE RICHARDS** 4600 HARGROVE DR LANHAM, MD US 20706

enoel@phalconusa.com

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

T: (240)623-4398 F: