

Machine Id CRK 1 Component Refrigeration Compressor Fluid {not provided} (2 GAL)

RECOMMENDATION

Resample at the next service interval to monitor.

WEAR

All component wear rates are normal.


CONTAMINATION

There is a high amount of silt (particulates < 14 microns in size) present in the oil. There is a trace of moisture present in the oil.

FLUID CONDITION

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

				~		
Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		USP0012284	USP224398	USP224391
Sample Date		Client Info		11 Jul 2024	06 Jun 2021	06 May 2021
Machine Age	hrs	Client Info		0	41240	37755
Oil Age	hrs	Client Info		0	0	0
Filter Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	Not Changd	Not Changd
Filter Changed		Client Info		N/A	Not Changd	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ATTENTION
Iron	ppm	ASTM D5185m	>8	2	0	<1
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	<1	0	0
Lead	ppm	ASTM D5185m	>2	0	0	0
Copper	ppm	ASTM D5185m	>8	0	<1	<1
Tin	ppm	ASTM D5185m	>4	<1	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Silicon	ppm	ASTM D5185m	>15	2	14	1
Potassium	ppm	ASTM D5185m	>20	1	0	0
Water	%	ASTM D6304	>0.01	A 0.046	▲ 0.094	▲ 0.082
ppm Water	ppm	ASTM D6304	>100	464	A 940.6	A 825.8
Particles >4µm		ASTM D7647	>2500	4 9541	🔺 38429	17404
Particles >6µm		ASTM D7647	>320	<u> </u>	▲ 5577	2738
Particles >14µm		ASTM D7647	>80	53	<u> </u>	64
Particles >21µm		ASTM D7647	>20	8	18	10
Particles >38µm		ASTM D7647	>4	0	2	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>18/15/13	🔺 20/18/13	🔺 22/20/14	21/19/13
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG	NEG
Codium				0	0	0
Sodium	ppm	ASTM D5185m		0	0	0
Boron	ppm	ASTM D5185m		2	2	2
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		0	1	0
Phosphorus	ppm	ASTM D5185m		0	1	0
Zinc	ppm	ASTM D5185m		0	5	0
Sulfur	ppm	ASTM D5185m		0	30	0
Acid Number (AN)	mg KOH/g	ASTM D974		0.014	0.022	0.016
Visc @ 40°C	cSt	ASTM D445		54.2	61.1	63.5



RACE ENGINEERING CORP Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 : USP0012284 12871 WESTERN AVE, SUITE E Sample No. Received : 12 Jul 2024 Lab Number : 06234999 GARDEN GROVE, CA Tested : 16 Jul 2024 Unique Number : 11123833 : 16 Jul 2024 - Doug Bogart US 92841 Diagnosed Test Package : IND 2 Contact: TODD CARTER Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. tcrace@verizon.net * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: (714)895-3488 F: (714)895-5125

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Ċ۶

Contact/Location: TODD CARTER - RACGAR Page 2 of 2