



CORROSION	NORMAL
CONTAMINANTS	NORMAL
COOLANT CONDITION	NORMAL

Machine Id
M09-0912 M09-0912
Component
2 Coolant
Fluid
{not provided} (--- GAL)

RECOMMENDATION

The fluid is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		JR0211435	---	---
Sample Date		Client Info		09 Jul 2024	---	---
Machine Age	hrs	Client Info		5041	---	---
Oil Age	hrs	Client Info		1566	---	---
Oil Changed		Client Info		N/A	---	---
Sample Status				NORMAL	---	---








CORROSION

Total Dissolved Solids				340.5	---	---
Coolant Appearance		*Visual	Clear	normal	---	---

CONTAMINANTS

There is no indication of any contamination in the coolant.

Boiling Point	°C	WC Method		225	---	---
Specific Gravity		*ASTM D1298		1.067	---	---
pH	Scale 0-14	ASTM D1287		7.96	---	---
Nitrites	ppm	AP-053:2009		NT	---	---
Reserve Alkalinity	Scale 0-20	*ASTM D1121		---	---	---
Percentage Glycol	%	ASTM D3321		50.0	---	---
Freezing Point	°F	ASTM D3321		-35	---	---
Carboxylate				n/a	---	---
Coolant Color		*Visual		Orange	---	---



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : JR0211435 **Received** : 15 Jul 2024
Lab Number : 06236742 **Tested** : 17 Jul 2024
Unique Number : 11125576 **Diagnosed** : 17 Jul 2024 - Jonathan Hester
Test Package : COOL- (Additional Tests: GlycolType, PQ)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

LUCK STONE - MILFORD
 19380 RICHMOND TURNPIKE
 MILFORD, VA
 US 22514
 Contact: JAMES MASON
 jmason@luckstone.com

T:
F: (804)633-7927