

Machine Id
41
Component
Natural Gas Engine
Fluid
PETRO CANADA SENTRON LD 3000 (--- GAL)

RECOMMENDATION

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		PCA0117249	PCA0117286	PCA0111895
Sample Date		Client Info		10 Jul 2024	30 May 2024	02 May 2024
Machine Age	hrs	Client Info		104442	103684	103036
Oil Age	hrs	Client Info		6940	6182	5532
Filter Age	hrs	Client Info		6940	6186	5532
Oil Changed		Client Info		N/A	Not Changd	Not Changd
Filter Changed		Client Info		N/A	Not Changd	Not Changd
Sample Status				NORMAL	MARGINAL	NORMAL

WEAR

All component wear rates are normal.

Iron	ppm	ASTM D5185m	>50	6	7	7
Chromium	ppm	ASTM D5185m	>4	<1	<1	1
Nickel	ppm	ASTM D5185m	>2	<1	0	1
Titanium	ppm	ASTM D5185m		<1	0	<1
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>9	2	2	<1
Lead	ppm	ASTM D5185m	>30	0	4	1
Copper	ppm	ASTM D5185m	>35	2	5	2
Tin	ppm	ASTM D5185m	>4	0	2	1
Vanadium	ppm	ASTM D5185m		<1	0	<1
White Metal	scalar	*Visual	NONE	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE

CONTAMINATION













Tests indicate that there is no fuel present in the oil. There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185m	>+100	3	3	3
Potassium	ppm	ASTM D5185m	>20	1	5	3
Fuel	%	ASTM D3524	>4.0	0.0	▲ 2.2	0.0
Water		WC Method	>0.1	NEG	NEG	NEG
Soot %	%	*ASTM D7844		0	0	0
Nitration	Abs/cm	*ASTM D7624	>20	3.9	5.0	4.6
Sulfation	Abs/.1mm	*ASTM D7415	>30	14.3	14.1	14.2
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG

FLUID CONDITION

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185m		0	2	0
Boron	ppm	ASTM D5185m	5	2	<1	0
Barium	ppm	ASTM D5185m	1	0	0	0
Molybdenum	ppm	ASTM D5185m	2	1	4	2
Manganese	ppm	ASTM D5185m	1	0	2	<1
Magnesium	ppm	ASTM D5185m	5	8	10	7
Calcium	ppm	ASTM D5185m	1220	1245	1452	1297
Phosphorus	ppm	ASTM D5185m	298	267	325	293
Zinc	ppm	ASTM D5185m	350	350	400	357
Sulfur	ppm	ASTM D5185m	1995	2204	2966	2618
Oxidation	Abs/.1mm	*ASTM D7414	>25	8.0	9.0	8.9
Acid Number (AN)	mg KOH/g	ASTM D8045	0.86	0.19	0.65	0.44
Base Number (BN)	mg KOH/g	ASTM D2896	3.9	3.91	3.41	3.47
Visc @ 100°C	cSt	ASTM D445	13.7	13.1	13.3	13.3



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0117249 **Received** : 16 Jul 2024
Lab Number : 06238559 **Tested** : 19 Jul 2024
Unique Number : 11127393 **Diagnosed** : 19 Jul 2024 - Doug Bogart
Test Package : MOB 2 (Additional Tests: FuelDilution, PercentFuel)

ENERVEST OPERATING - HAYS BOOSTER
 1705 BREAKS PARK ROAD
 HAYS, VA
 US 24256
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: