

## Machine Id EASG 1014220 Component Diesel Engine Filuid DIESEL ENGINE OIL SAE 40 (--- GAL)

## RECOMMENDATION

Resample at the next service interval to monitor. The fluid was not specified, however, a fluid match indicates that this fluid is (GENERIC) DIESEL ENGINE OIL SAE 40. Please confirm. Please specify the component make and model with your next sample.

WEAR

All component wear rates are normal.


## CONTAMINATION


There is no indication of any contamination in the oil.

## **FLUID CONDITION**

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC0911169	WC0641975	WC0438852
Sample Date		Client Info		23 May 2024	30 Jan 2022	07 May 2020
Machine Age	hrs	Client Info		6522	0	1538
Oil Age	hrs	Client Info		0	0	0
Filter Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Changed	Changed	Changed
Filter Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	NORMAL
Iron	ppm	ASTM D5185m	>100	12	11	19
Chromium	ppm	ASTM D5185m	>20	0	<1	<1
Nickel	ppm	ASTM D5185m	>4	0	0	0
Titanium	ppm	ASTM D5185m		<1	<1	8
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>20	4	5	4
Lead	ppm	ASTM D5185m	>40	0	2	0
Copper	ppm	ASTM D5185m	>330	2	7	7
Tin	ppm	ASTM D5185m	>15	0	<1	<1
Vanadium	ppm	ASTM D5185m		0	<1	0
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Silicon	ppm	ASTM D5185m	>25	4	5	5
Potassium	ppm	ASTM D5185m	>20	2	<1	3
Fuel	ppm	WC Method	>5	- <1.0	<1.0	<1.0
Water		WC Method		NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
Soot %	%	*ASTM D7844	>3	0.2	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>20	8.2	8.0	9
Sulfation	Abs/.1mm	*ASTM D7415	>30	21.6	26.7	19.9
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
Sodium	ppm	ASTM D5185m		19	2	4
Boron	ppm	ASTM D5185m	250	286	331	137
Barium	ppm	ASTM D5185m	10	0	0	<1
Molybdenum	ppm	ASTM D5185m	100	86	102	53
Manganese	ppm	ASTM D5185m	450	0	<1	<1
Magnesium	ppm	ASTM D5185m	450	481	532	627
Calcium	ppm	ASTM D5185m	3000	1509	1475	1410
Phosphorus	ppm	ASTM D5185m	1150	1018	812	678
Zinc	ppm	ASTM D5185m	1350	1278	862	764
Sulfur	ppm	ASTM D5185m	4250	3697	2588	2634
Oxidation	Abs/.1mm	*ASTM D7414	>25	17.0	26.1	16
Base Number (BN)	mg KOH/g	ASTM D2896	8.5	7.5	7.2	6.8
Visc @ 100°C	cSt	ASTM D445	14.4	12.8	12.6	13.3





Contact/Location: LUIS LAPIERRE - DOLWIL Page 2 of 2