



RAPPORT D'ANALYSE D'HUILE

| | |
|----------------|---------------|
| USURE | NORMAL |
| CONTAMINATION | NORMAL |
| ÉTAT DU FLUIDE | NORMAL |

Secteur
[203386]
 Identité de la machine
74547965

Composant
Moteur diesel
 Fluide
SHELL ROTELLA T 15W40 (--- GAL)

RECOMMENDATION

Resample at the next service interval to monitor.

| Test | UOM | Method | Limit/Abn | Current | History1 | History2 |
|---------------------|-----|-------------|-----------|--------------------|----------|----------|
| Numéro d'échant. | | Client Info | | CU0020990 | --- | --- |
| Date d'échant. | | Client Info | | 29 Jun 2023 | --- | --- |
| Âge d la Machine | hrs | Client Info | | 3275 | --- | --- |
| Âge de l'huile | hrs | Client Info | | 25 | --- | --- |
| Âge du filtre | hrs | Client Info | | 25 | --- | --- |
| Huile changée | | Client Info | | Changed | --- | --- |
| Filtre changé | | Client Info | | Changed | --- | --- |
| Statut de l'échant. | | | | NORMAL | --- | --- |

USURE

All component wear rates are normal.

| | | | | | | |
|-----------|-----|---------------|------|--------------|-----|-----|
| Fer | ppm | ASTM D5185(m) | >90 | 14 | --- | --- |
| Chrome | ppm | ASTM D5185(m) | >20 | <1 | --- | --- |
| Nickel | ppm | ASTM D5185(m) | >2 | <1 | --- | --- |
| Titane | ppm | ASTM D5185(m) | >2 | 0 | --- | --- |
| Argent | ppm | ASTM D5185(m) | >2 | 0 | --- | --- |
| Aluminium | ppm | ASTM D5185(m) | >20 | 2 | --- | --- |
| Plomb | ppm | ASTM D5185(m) | >40 | 0 | --- | --- |
| Cuivre | ppm | ASTM D5185(m) | >330 | 1 | --- | --- |
| Étain | ppm | ASTM D5185(m) | >15 | 0 | --- | --- |
| Vanadium | ppm | ASTM D5185(m) | | 0 | --- | --- |

CONTAMINATION










Elevated aluminum (Al) and/or lead (Pb) and potassium (K) levels in your metals analysis are likely a result of solder flux release into the lubricant and is common on new equipment/components. There is no indication of any contamination in the oil.

| | | | | | | |
|----------------|----------|---------------|------|----------------|-----|-----|
| Silicium | ppm | ASTM D5185(m) | >25 | 2 | --- | --- |
| Potassium | ppm | ASTM D5185(m) | >20 | 6 | --- | --- |
| Essence | | WC Method | >3.0 | <1.0 | --- | --- |
| Glycol | | WC Method | | NEG | --- | --- |
| % de suie | % | ASTM D7844* | >6 | 0 | --- | --- |
| Nitration | Abs/cm | ASTM D7624* | >20 | 5.6 | --- | --- |
| Sulfatation | Abs/.1mm | ASTM D7415* | >30 | 20.6 | --- | --- |
| Eau émulsifiée | scalar | Visual* | >0.2 | NEG | --- | --- |

ÉTAT DU FLUIDE

The condition of the oil is acceptable for the time in service.

| | | | | | | |
|------------|----------|---------------|------|--------------|-----|-----|
| Sodium | ppm | ASTM D5185(m) | | 2 | --- | --- |
| Bore | ppm | ASTM D5185(m) | 35 | 169 | --- | --- |
| Baryum | ppm | ASTM D5185(m) | 0 | 0 | --- | --- |
| Molybdène | ppm | ASTM D5185(m) | 0 | <1 | --- | --- |
| Manganèse | ppm | ASTM D5185(m) | 0 | <1 | --- | --- |
| Magnésium | ppm | ASTM D5185(m) | 10 | 13 | --- | --- |
| Calcium | ppm | ASTM D5185(m) | 2340 | 2152 | --- | --- |
| Phosphore | ppm | ASTM D5185(m) | 1110 | 1002 | --- | --- |
| Zinc | ppm | ASTM D5185(m) | 1210 | 1103 | --- | --- |
| Soufre | ppm | ASTM D5185(m) | 3890 | 2948 | --- | --- |
| Oxydation | Abs/.1mm | ASTM D7414* | >25 | 16.6 | --- | --- |
| Visc 100°C | cSt | ASTM D7279(m) | 15.7 | 14.6 | --- | --- |



ISO 17025:2017
Accredited
Laboratory

Laboratoire : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
N° d'échantillon : CU0020990 **Reçu** : 05 Jul 2023
N° de laboratoire : 02567915 **Diagnostiqué** : 05 Jul 2023
Numéro unique : 5604961 **Diagnostiqueur** : Wes Davis
Analyse : MOB 1

7200 TRANS CANADA HWY.
 POINTE CLAIRE, QC
 CA H9R 1C2
 Contact: Karelle Paradis
 karelle.paradis@cummins.com
 T: (514)695-8410
 F: (514)695-5246

Pour discuter ce rapport, contacter le service à la clientèle au 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.