



RAPPORT D'ANALYSE D'HUILE

USURE	NORMAL
CONTAMINATION	NORMAL
ÉTAT DU FLUIDE	NORMAL

Secteur
[49237]
 Identité de la machine
2296435

Composant
Moteur diesel
 Fluide
NOT GIVEN (--- GAL)

RECOMMENDATION

Resample at the next service interval to monitor. The fluid was not specified, however, a fluid match indicates that this fluid is SAE 40 Diesel Engine Oil. Please confirm the oil type and grade, and specify the brand of the oil on your next sample. Please specify the component make and model with your next sample.

USURE

All component wear rates are normal.










CONTAMINATION

There is no indication of any contamination in the oil.

ÉTAT DU FLUIDE

The condition of the oil is acceptable for the time in service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Numéro d'échant.		Client Info		CU0021647	CU0016479	---
Date d'échant.		Client Info		13 Nov 2023	29 Sep 2020	---
Âge d la Machine	hrs	Client Info		0	0	---
Âge de l'huile	hrs	Client Info		0	0	---
Âge du filtre	hrs	Client Info		0	0	---
Huile changée		Client Info		N/A	N/A	---
Filtre changé		Client Info		N/A	N/A	---
Statut de l'échant.				NORMAL	NORMAL	---
Fer	ppm	ASTM D5185(m)	>100	4	7	---
Chrome	ppm	ASTM D5185(m)	>20	0	<1	---
Nickel	ppm	ASTM D5185(m)	>4	0	<1	---
Titane	ppm	ASTM D5185(m)		0	<1	---
Argent	ppm	ASTM D5185(m)	>3	0	0	---
Aluminium	ppm	ASTM D5185(m)	>20	1	2	---
Plomb	ppm	ASTM D5185(m)	>40	0	<1	---
Cuivre	ppm	ASTM D5185(m)	>330	<1	3	---
Étain	ppm	ASTM D5185(m)	>15	0	0	---
Vanadium	ppm	ASTM D5185(m)		0	0	---
Métal blanc	scalar	Visual*	NONE	NONE	---	---
Bronze	scalar	Visual*	NONE	NONE	---	---
Silicium	ppm	ASTM D5185(m)	>25	6	7	---
Potassium	ppm	ASTM D5185(m)	>20	0	<1	---
Essence		WC Method	>5	<1.0	<1.0	---
Glycol		WC Method		NEG	NEG	---
% de suie	%	ASTM D7844*	>3	0	0	---
Nitration	Abs/cm	ASTM D7624*	>20	7.5	6.6	---
Sulfatation	Abs/.1mm	ASTM D7415*	>30	23.4	28.1	---
Limon	scalar	Visual*	NONE	NONE	---	---
Débris	scalar	Visual*	NONE	NONE	---	---
Saleté	scalar	Visual*	NONE	NONE	---	---
Apparence	scalar	Visual*	NORML	NORML	---	---
Odeur	scalar	Visual*	NORML	NORML	---	---
Eau émulsifiée	scalar	Visual*	>0.2	NEG	NEG	---
Sodium	ppm	ASTM D5185(m)		3	1	---
Bore	ppm	ASTM D5185(m)		44	41	---
Baryum	ppm	ASTM D5185(m)		<1	0	---
Molybdène	ppm	ASTM D5185(m)		48	37	---
Manganèse	ppm	ASTM D5185(m)		0	<1	---
Magnésium	ppm	ASTM D5185(m)		822	477	---
Calcium	ppm	ASTM D5185(m)		1165	1701	---
Phosphore	ppm	ASTM D5185(m)		723	925	---
Zinc	ppm	ASTM D5185(m)		805	1035	---
Soufre	ppm	ASTM D5185(m)		1876	1997	---
Oxydation	Abs/.1mm	ASTM D7414*	>25	18.3	23.0	---
Visc 100°C	cSt	ASTM D7279(m)		13.7	13.4	---



ISO 17025:2017
Accredited
Laboratory

Laboratoire : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **CUMMINS EASTERN CANADA INC.**
N° d'échantillon : CU0021647 **Reçu** : 14 Nov 2023 122 CLYDE AVENUE
N° de laboratoire : 02596109 **Diagnostiqué** : 14 Nov 2023 MOUNT PEARL, NL
Numéro unique : 5681189 **Diagnostiqueur** : Kevin Marson CA A1N 4S3
Analyse : MOB 1 (Additional Tests: Visual)

Pour discuter ce rapport, contacter le service à la clientèle au 1-800-268-2131.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

La validez de los resultados y la interpretación se basan en la muestra y la información proporcionada.

Contact: DARRYL CAREY

DARRYL.CAREY@CUMMINS.COM

T: (709)747-1135

F: (709)747-1084