



RAPPORT DU LIQUIDE DE REFROIDISSEMENT

CORROSION
CONTAMINANTS
ÉTAT DU LIQUIDE REFROIDISSEMENT

NORMAL
NORMAL
NORMAL

Secteur

[49242]

Identité de la machine

NO UNIT CU0021657

Composant

Liquide de refroidissement

Fluid

EXTENDED LIFE COOLANT (--- GAL)

RECOMMENDATION

Resample at the next service interval to monitor. The fluid was not specified, however, a fluid match indicates that this fluid is (GENERIC) EXTENDED LIFE COOLANT. Please confirm.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Numéro d'échant.		Client Info		CU0021657	---	---
Date d'échant.		Client Info		31 Oct 2023	---	---
Âge d la Machine	hrs	Client Info		0	---	---
Âge de l'huile	hrs	Client Info		0	---	---
Huile changée		Client Info		N/A	---	---
Statut de l'échant.				NORMAL	---	---

CORROSION

All component wear rates are normal.

Fer	ppm	ASTM D5185(m)	>15	0	---	---
Aluminium	ppm	ASTM D5185(m)	>10	3	---	---
Cuivre	ppm	ASTM D5185(m)	>10	0	---	---
Plomb	ppm	ASTM D5185(m)	>10	0	---	---
Étain	ppm	ASTM D5185(m)	>10	0	---	---
Argent	ppm	ASTM D5185(m)	>10	<1	---	---
Zinc	ppm	ASTM D5185(m)	>10	0	---	---

CONTAMINANTS








There is no indication of any contamination in the coolant.

Calcium	ppm	ASTM D5185(m)	>100	5	---	---
Magnésium	ppm	ASTM D5185(m)	>40	<1	---	---
Apparence	scalar	Visual*	NORML	NORML	---	---
Odeur	scalar	Visual*	NORML	NORML	---	---
Apparence du liquide de refroidissement		Visual*	Clear	Clear	---	---

ÉTAT DU LIQUIDE REFROIDISSEMENT

The condition of the coolant is acceptable for the time in service.

Densité		ASTM D1298*		1.068	---	---
pH	Scale 0-14	ASTM D1287*	9.0	8.32	---	---
Nitrites	ppm	Alcan Test Kit*		680	---	---
Réserve d'alcalinité	Scale 0-20	ASTM D1121*		3.5	---	---
Pourcentage de glycol	%	ASTM D3321*	50	50.7	---	---
Point de congélation	°C	ASTM D3321*	-40	-37	---	---
Carboxylate				---	---	---
Silicium	ppm	ASTM D5185(m)		15	---	---
Phosphore	ppm	ASTM D5185(m)		30	---	---
Bore	ppm	ASTM D5185(m)		15	---	---
Molybdène	ppm	ASTM D5185(m)		538	---	---
Sodium	ppm	ASTM D5185(m)		7212	---	---
Potassium	ppm	ASTM D5185(m)		180	---	---
Couleur du liquide de refroidissement		Visual*	Orange/R	Red	---	---



Laboratoire : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **CUMMINS EASTERN CANADA INC.**
N° d'échantillon : CU0021657 **Reçu** : 31 Jan 2024 122 CLYDE AVENUE
N° de laboratoire : 02612641 **Diagnostiqué** : 01 Feb 2024 MOUNT PEARL, NL
Numéro unique : 5721736 **Diagnostiqueur** : Wes Davis CA A1N 4S3
Analyse : COOL

Pour discuter ce rapport, contacter le service à la clientèle au 1-800-268-2131.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

La validez de los resultados y la interpretación se basan en la muestra y la información proporcionada.

Contact: DARRYL CAREY
DARRYL.CAREY@CUMMINS.COM

T: (709)747-1135

F: (709)747-1084