




PROBLEM SUMMARY

Sample Rating Trend




DEGRADATION




Machine Id
PARKER BOILERS 1
 Component
Heat Transfer Fluid
 Fluid
PETRO CANADA CALFLO AF (600 GAL)

COMPONENT CONDITION SUMMARY


Acid Number



Viscosity @ 40°C



GCD Spectrum



RECOMMENDATION

AN is severely elevated in conjunction with Pentane insolubles elevated. The GCD 90% distillation point is elevated. This data indicates oxidation and has caused heavy sludge and insolubles in the system. The viscosity has elevated significantly confirming sludge and system fouling. Take another sample and purge oil before capturing sample to confirm results.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	SEVERE	SEVERE
Acid Number (AN)	mg KOH/g	ASTM D974*	0.03	6.04	3.17	1.55
Visc @ 40°C	cSt	ASTM D7279(m)	32.7	41.2	33.0	32.6
Pentane Insolubles	%	ASTM D893(m)*		3.50	1.09	0.257
(GCD) 90% Distillation Point	°C	ASTM D2887*	475	489.0	485.0	475.6

Customer Id: CUSANY
 Sample No.: WC1234567
 Lab Number: 01234567
 Test Package: HTTFL



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Ron LeBlanc +1 (541)678-7044
Ronald.LeBlancSr@HFSinclair.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

19 Apr 2016 Diag: Steven Slanker

DEGRADATION



Acid number and pentane insoluble are very high. Recommend drain, flush and recharge system with fresh Calflo AF. Pentane Insolubles levels are severely high. Acid Number (AN) is severely high. COC Flash Point is marginally low.

view report



12 Oct 2013 Diag: Gaston Arseneault

DEGRADATION



Even though it appears the acid level (Acid Number) dropped a bit, it is still very high and exceeds condemning limits. Therefore we can expect it to rise even further. If an oil change was done then it appears a fair amount of the previously acidic oil was left in the system, or the fluid still sees contamination from an acidic material. If a system cleaning, flushing and refill has not taken place since the last sample we recommend to plan for it so the fluid can look healthy again. Acid Number (AN) is severely high.

view report



22 Sep 2012 Diag: Gaston Arseneault

DEGRADATION



The TAN is still rising and is now well beyond condemning limits. The insoluble solids are also exceeding severe warning limits. We have been advising for years to change this fluid and we say it again. The fluid needs to be replaced and the system thoroughly cleaned before production related issues start to appear if it hasn't started already.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



DEGRADATION



Machine Id
PARKER BOILERS 1
 Component
Heat Transfer Fluid
 Fluid
PETRO CANADA CALFLO AF (600 GAL)

DIAGNOSIS

Recommendation

AN is severely elevated in conjunction with Pentane insolubles elevated. The GCD 90% distillation point is elevated. This data indicates oxidation and has caused heavy sludge and insolubles in the system. The viscosity has elevated significantly confirming sludge and system fouling.

Take another sample and purge oil before capturing sample to confirm results.

Contamination

Pentane Insolubles levels are severely high.

Fluid Condition

Acid Number (AN) is severely high. Visc @ 40°C is abnormally high. (GCD) 90% Distillation Point is marginally high.

SAMPLE INFORMATION

	method	limit/base	current	history 1	history 2
Sample Number	Client Info		WC	PC	PC
Sample Date	Client Info		13 Oct 2022	19 Apr 2016	12 Oct 2013
Machine Age	days	Client Info	0	0	0
Oil Age	days	Client Info	3	4	1
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	SEVERE	SEVERE

WEAR METALS

	method	limit/base	current	history 1	history 2	
Iron	ppm	ASTM D5185(m)	>200	93	63	82
Chromium	ppm	ASTM D5185(m)	>21	0	0	0
Nickel	ppm	ASTM D5185(m)	>21	0	0	0
Titanium	ppm	ASTM D5185(m)	>21	0	0	0
Silver	ppm	ASTM D5185(m)	>21	0	0	0
Aluminum	ppm	ASTM D5185(m)	>21	<1	0	<1
Lead	ppm	ASTM D5185(m)	>21	<1	<1	<1
Copper	ppm	ASTM D5185(m)	>21	<1	<1	<1
Tin	ppm	ASTM D5185(m)	>21	0	<1	<1
Antimony	ppm	ASTM D5185(m)	>21	<1	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES

	method	limit/base	current	history 1	history 2	
Boron	ppm	ASTM D5185(m)	0	<1	<1	<1
Barium	ppm	ASTM D5185(m)	0	0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0	0
Manganese	ppm	ASTM D5185(m)	0	1	<1	<1
Magnesium	ppm	ASTM D5185(m)	0	0	0	0
Calcium	ppm	ASTM D5185(m)	0	<1	<1	4
Phosphorus	ppm	ASTM D5185(m)	270	267	238	226
Zinc	ppm	ASTM D5185(m)	0	3	2	3
Sulfur	ppm	ASTM D5185(m)	10	21	43	52
Lithium	ppm	ASTM D5185(m)		<1	<1	<1

CONTAMINANTS

	method	limit/base	current	history 1	history 2	
Silicon	ppm	ASTM D5185(m)	>25	1	<1	2
Sodium	ppm	ASTM D5185(m)	>21	<1	<1	<1
Potassium	ppm	ASTM D5185(m)	>20	<1	0	0
Water	%	ASTM D6304*	>0.0601	0.026	0.012	0.004
ppm Water	ppm	ASTM D6304*	>601	260.5	126.7	41.7


FLUID DEGRADATION

	method	limit/base	current	history 1	history 2	
Acid Number (AN)	mg KOH/g	ASTM D974*	0.03	6.04	3.17	1.55




OIL ANALYSIS REPORT


Acid Number




Viscosity @ 40°C




Gas Chromatography (GCD)



GCD Spectrum



Flash Point (°C)



VISUAL	method	limit/base	current	history 1	history 2	
White Metal	scalar	Visual*	NONE	NONE	VLITE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	VLITE
Debris	scalar	Visual*	NONE	NONE	VLITE	VLITE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.0601	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history 1	history 2	
Visc @ 40°C	cSt	ASTM D7279(m)	32.7	▲ 41.2	33.0	32.6
COC Flash Point	°C	ASTM D92*	224	206	▲ 192	202

SEDIMENT	method	limit/base	current	history 1	history 2
Pentane Insolubles	%	ASTM D893(m)*	● 3.50	● 1.09	0.257

SIMULATED DISTILLATON (GCD)	method	limit/base	current	history 1	history 2	
(GCD) % < 335°C	°C	ASTM D2887*	2.5	2.86	3.00	3.57
(GCD) Initial Boiling Point	°C	ASTM D2887*		190.3	243.0	187.0
(GCD) 5% Distillation Point	°C	ASTM D2887*		349.7	345.5	341.4
(GCD) 10% Distillation Point	°C	ASTM D2887*	367	368.4	364.7	361.2
(GCD) 20% Distillation Point	°C	ASTM D2887*		389.0	386.1	382.5
(GCD) 30% Distillation Point	°C	ASTM D2887*		403.1	400.6	397.2
(GCD) 40% Distillation Point	°C	ASTM D2887*		414.4	412.4	409.0
(GCD) 50% Distillation Point	°C	ASTM D2887*	421	424.9	423.3	419.8
(GCD) 60% Distillation Point	°C	ASTM D2887*		435.7	434.5	430.7
(GCD) 70% Distillation Point	°C	ASTM D2887*		448.2	446.8	442.6
(GCD) 80% Distillation Point	°C	ASTM D2887*		464.1	461.8	456.3
(GCD) 90% Distillation Point	°C	ASTM D2887*	475	▲ 489.0	485.0	475.6
(GCD) FBP% Distillation Point	°C	ASTM D2887*		556.2	593.9	531.2

SAMPLE IMAGES	method	limit/base	current	history 1	history 2
---------------	--------	------------	---------	-----------	-----------

Color



Bottom



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC1234567 **Received** : 24 Oct 2022
Lab Number : **01234567** **Diagnosed** : 16 Nov 2022
Unique Number : 12345678 **Diagnostician** : Ron LeBlanc
Test Package : HTTFL (Additional Tests: GC-PerFuel, Spat, TAN Man)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Cusany Logistics Inc.
 1212 Industrial Place
 Centerville, OH
 USA 75900
 Contact: Jim Leduc
 jim.leduc@cusanylogisticsinc.com
 T: (305)555-1212
 F: (305)555-1222