




# PROBLEM SUMMARY

Sample Rating Trend



**WATER**



Area

## UTILITIES

Machine Id

**K6601E (S/N L97K-06758)**

Component


**Refrigeration Compressor**

Fluid


**TRANE TRANE COMPRESSOR OIL 22 (20 GAL)**

### COMPONENT CONDITION SUMMARY

▲ Particle Trend



▲ Water



### RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

### PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ATTENTION	ABNORMAL
Water	%	ASTM D6304	>0.01	▲ 0.010	0.001	0.001
ppm Water	ppm	ASTM D6304	>100	▲ 102.6	10.8	9.1
Particles >4µm		ASTM D7647	>640	▲ 3920	▲ 1094	▲ 2660
Particles >6µm		ASTM D7647	>160	▲ 731	▲ 168	▲ 335
Oil Cleanliness		ISO 4406 (c)	>16/14/12	▲ 19/17/12	▲ 17/15/11	▲ 19/16/11

Customer Id: CUSANY  
 Sample No.: WC1234567  
 Lab Number: 01234567  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Doug Bogart +1 (800)237-1369 x4016  
[dougb@wearcheckusa.com](mailto:dougb@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component if applicable.

## HISTORICAL DIAGNOSIS

### 05 May 2022 Diag: Doug Bogart

ISO



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 30 Jul 2021 Diag: Jonathan Hester

ISO



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report




### 25 May 2021 Diag: Angela Borella

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Area  
**UTILITIES**  
 Machine Id  
**K6601E (S/N L97K-06758)**

Component  
**Refrigeration Compressor**  
 Fluid  
**TRANE TRANE COMPRESSOR OIL 22 (20 GAL)**

## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. There is a trace of moisture present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history 1	history 2
Sample Number			<b>WC0723586</b>	WC0686389	WC0593218
Sample Date			<b>28 Jul 2022</b>	05 May 2022	30 Jul 2021
Machine Age	hrs		<b>95376</b>	95376	0
Oil Age	hrs		<b>95376</b>	95376	0
Oil Changed			<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ATTENTION	ABNORMAL

## WEAR METALS

	method	limit/base	current	history 1	history 2
Iron	ppm ASTM D5185m	>50	<b>6</b>	6	4
Chromium	ppm ASTM D5185m	>10	<b>0</b>	0	0
Nickel	ppm ASTM D5185m		<b>1</b>	0	0
Titanium	ppm ASTM D5185m		<b>0</b>	0	0
Silver	ppm ASTM D5185m		<b>3</b>	0	0
Aluminum	ppm ASTM D5185m	>10	<b>2</b>	0	0
Lead	ppm ASTM D5185m	>10	<b>0</b>	0	0
Copper	ppm ASTM D5185m	>50	<b>0</b>	<1	<1
Tin	ppm ASTM D5185m	>10	<b>4</b>	3	<1
Antimony	ppm ASTM D5185m		<b>---</b>	---	0
Vanadium	ppm ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm ASTM D5185m		<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history 1	history 2
Boron	ppm ASTM D5185m		<b>&lt;1</b>	0	<1
Barium	ppm ASTM D5185m		<b>0</b>	1	0
Molybdenum	ppm ASTM D5185m		<b>0</b>	0	0
Manganese	ppm ASTM D5185m		<b>0</b>	0	0
Magnesium	ppm ASTM D5185m		<b>0</b>	0	0
Calcium	ppm ASTM D5185m		<b>0</b>	0	0
Phosphorus	ppm ASTM D5185m		<b>21</b>	6	2
Zinc	ppm ASTM D5185m		<b>6</b>	4	0
Sulfur	ppm ASTM D5185m		<b>2</b>	7	39

## CONTAMINANTS

	method	limit/base	current	history 1	history 2
Silicon	ppm ASTM D5185m	>15	<b>8</b>	5	4
Sodium	ppm ASTM D5185m		<b>0</b>	0	0
Potassium	ppm ASTM D5185m	>20	<b>0</b>	<1	0
Water	% ASTM D6304	>0.01	<b>▲ 0.010</b>	0.001	0.001
ppm Water	ppm ASTM D6304	>100	<b>▲ 102.6</b>	10.8	9.1

## FLUID CLEANLINESS

	method	limit/base	current	history 1	history 2
Particles >4µm	ASTM D7647	>640	<b>▲ 3920</b>	▲ 1094	▲ 2660
Particles >6µm	ASTM D7647	>160	<b>▲ 731</b>	▲ 168	▲ 335
Particles >14µm	ASTM D7647	>40	<b>31</b>	17	13
Particles >21µm	ASTM D7647	>10	<b>7</b>	4	2
Particles >38µm	ASTM D7647	>3	<b>1</b>	0	0
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>16/14/12	<b>▲ 19/17/12</b>	▲ 17/15/11	▲ 19/16/11


## FLUID DEGRADATION

	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g ASTM D974		<b>0.014</b>	0.047	0.03




# OIL ANALYSIS REPORT

### ▲ Particle Trend



### ▲ Water




VISUAL	method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	47.9	53.9	47.8

### SAMPLE IMAGES

method	limit/base	current	history 1	history 2
Color				
Bottom				

### GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC1234567 **Received** : 02 Aug 2022  
**Lab Number** : 01234567 **Diagnosed** : 03 Aug 2022  
**Unique Number** : 12345678 **Diagnostician** : Doug Bogart  
**Test Package** : IND 2 ( Additional Tests: PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**Cusany Logistics Inc.**  
 1212 Industrial Place  
 Centerville, OH  
 USA 75900

Contact: Jim Leduc  
jim.leduc@cusanylogisticsinc.com

T: (305)555-1212  
F: (305)555-1222