




# PROBLEM SUMMARY

Sample Rating Trend




**WATER**




Machine Id  
**YORK GM TECH CTR MOCK UP CH 1 (S/N SNNM-624800)**  
 Component  
**Refrigeration Compressor**  
 Fluid  
**YORK H (--- GAL)**

## COMPONENT CONDITION SUMMARY

▲ Silicon (ppm)



▲ Water



## RECOMMENDATION

No corrective action is recommended at this time. We recommend an early resample to monitor this condition. ( Customer Sample Comment: Routine maintenance )

## PROBLEMATIC TEST RESULTS

Sample Status				<b>ABNORMAL</b>	NORMAL	NORMAL
Silicon	ppm	ASTM D5185m	>15	▲ <b>24</b>	8	5
Water	%	ASTM D6304	>0.01	▲ <b>0.013</b>	0.008	0.008
ppm Water	ppm	ASTM D6304	>100	▲ <b>130.1</b>	82.1	88.4

Customer Id: CUSANY  
 Sample No.: WC1234567  
 Lab Number: 01234567  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Doug Bogart +1 (800)237-1369 x4016  
[dougb@wearcheckusa.com](mailto:dougb@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Resample	---	---	?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

30 Sep 2021 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



16 Dec 2020 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



05 Oct 2020 Diag: Angela Borella

WATER



Resample at the next service interval to monitor. All component wear rates are normal. There is a trace of moisture present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Machine Id  
**YORK GM TECH CTR MOCK UP CH 1 (S/N SNNM-624800)**  
 Component  
**Refrigeration Compressor**  
 Fluid  
**YORK H (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

No corrective action is recommended at this time. We recommend an early resample to monitor this condition. ( Customer Sample Comment: Routine maintenance )

### Wear

All component wear rates are normal.

### ▲ Contamination

There is a trace of moisture present in the oil. Elemental level of silicon (Si) above normal.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history 1	history 2
Sample Number			<b>WC0618927</b>	WC0507736	WC0514747
Sample Date			<b>19 Oct 2022</b>	30 Sep 2021	16 Dec 2020
Machine Age	hrs		<b>12588</b>	12056	7001
Oil Age	hrs		<b>12588</b>	0	7001
Oil Changed			<b>N/A</b>	N/A	Not Changd
Sample Status			<b>ABNORMAL</b>	NORMAL	NORMAL

## WEAR METALS

	method	limit/base	current	history 1	history 2
Iron	ppm ASTM D5185m	>50	<b>2</b>	4	2
Chromium	ppm ASTM D5185m	>10	<b>0</b>	0	0
Nickel	ppm ASTM D5185m		<b>0</b>	0	0
Titanium	ppm ASTM D5185m		<b>0</b>	0	0
Silver	ppm ASTM D5185m		<b>0</b>	<1	0
Aluminum	ppm ASTM D5185m	>10	<b>2</b>	<1	<1
Lead	ppm ASTM D5185m	>10	<b>0</b>	0	4
Copper	ppm ASTM D5185m	>50	<b>0</b>	<1	0
Tin	ppm ASTM D5185m	>10	<b>&lt;1</b>	<1	0
Antimony	ppm ASTM D5185m		<b>---</b>	0	0
Vanadium	ppm ASTM D5185m		<b>&lt;1</b>	0	0
Cadmium	ppm ASTM D5185m		<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history 1	history 2
Boron	ppm ASTM D5185m	0	<b>0</b>	2	1
Barium	ppm ASTM D5185m	0	<b>0</b>	0	0
Molybdenum	ppm ASTM D5185m	0	<b>0</b>	0	0
Manganese	ppm ASTM D5185m	0	<b>&lt;1</b>	<1	0
Magnesium	ppm ASTM D5185m	0	<b>0</b>	0	0
Calcium	ppm ASTM D5185m	0	<b>0</b>	0	0
Phosphorus	ppm ASTM D5185m	0	<b>9</b>	4	0
Zinc	ppm ASTM D5185m	0	<b>0</b>	0	0
Sulfur	ppm ASTM D5185m	0	<b>0</b>	26	0

## CONTAMINANTS

	method	limit/base	current	history 1	history 2
Silicon	ppm ASTM D5185m	>15	<b>▲ 24</b>	8	5
Sodium	ppm ASTM D5185m		<b>0</b>	0	<1
Potassium	ppm ASTM D5185m	>20	<b>0</b>	0	0
Water	% ASTM D6304	>0.01	<b>▲ 0.013</b>	0.008	0.008
ppm Water	ppm ASTM D6304	>100	<b>▲ 130.1</b>	82.1	88.4


## FLUID DEGRADATION

	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g ASTM D974	0.02	<b>0.016</b>	0.015	0.015




# OIL ANALYSIS REPORT

▲ Silicon (ppm)




▲ Water







VISUAL	method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	68.0	57.0	56.8

SAMPLE IMAGES	method	limit/base	current	history 1	history 2
---------------	--------	------------	---------	-----------	-----------



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC1234567 **Received** : 27 Oct 2022  
**Lab Number** : 01234567 **Diagnosed** : 01 Nov 2022  
**Unique Number** : 12345678 **Diagnostician** : Doug Bogart  
**Test Package** : IND 2

**Cusany Logistics Inc.**  
 1212 Industrial Place  
 Centerville, OH  
 USA 75900  
 Contact: Jim Leduc  
 jim.leduc@cusanylogisticsinc.com  
 T: (305)555-1212  
 F: (305)555-1222

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)